CITY OF ALBUQUERQUE



November 5, 2018

Tierra West LLC. Ron Bohannan 5571 Midway Park Pl NE, Albuquerque NM 87109

Re: Maverik – Comanche Princeton 3737 Princeton Dr. NE 87107 Traffic Circulation Layout


Engineer's/Architect's Stamp 10-28-18 (G16D029)

Dear Mr. Bohannan,

Based upon the information provided in your submittal received 10-28-18, the above referenced plan cannot be approved for Building Permit until the following comments are addressed:

- The ADA access aisles shall have the words "NO PARKING" in capital letters, each of which shall be at least one foot high and at least two inches wide, placed at the rear of the parking space so as to be close to where an adjacent vehicle's rear tire would be placed. (66-1-4.1.B NMSA 1978)
- Motorcycle parking spaces shall be designated by its own conspicuously posted upright sign, either free-standing or wall mounted per the zoning code.
- An Approved TIS from both COA and NM-DOT is required before TCL approval.
- 4. The maximum width of the access entry should be 35'.
- 5. Please provide the distance from the intersection for the North entrance.
- 6. Please provide the distance from the property line for the south entrance.
- 7. Refer to the picture below:

www.cabq.gov



PO Box 1293

Albuquerque

NM 87103

CITY OF ALBUQUERQUE



Resubmit a revised plan along with fully completed Drainage Transportation Information Sheet to front counter personnel for log in and evaluation by Transportation. PDF copies of the plans and submittal package must be emailed to PLNDRS@cabq.gov at time of resubmittal. If you have any questions, please contact Racquel Michel (505) 924-3991 or me at 924-3675.

Sincerely,

Racquel M. Michel, P.E.

Traffic Engineer, Planning Dept. Development Review Services

PO Box 1293

Mojgan Maadandar, E.I.

Associate Engineer, Planning Dept. Development Review Services

Albuquerque

MM via: email

NM 87103

C: CO Clerk, File

www.cabq.gov