HYDROLOGY G16/D50 PITTSBURG PAINT & GLASS

G16 / D50

PITTSBURG

PAINT + GLASS

1 PLAN

CITY OF ALBUQUERQUE
MUNICIPAL DEVELOPMENT DEPARTMENT
ENGINEERING DIVISION

HYDROLOGY SECTION PROJ. NO. G16 DATE: 12/19/83

PLANNING DIVISION NO. _____

CONFERENCE RECAP

SUBJECT: Parcel 4 of Hoan Addn Pittsburg Point & Gibson

	WHO	REPRESENTING
ATTENDANCE:	John Armstrong	City
	Jim Espinoza	Per Engineering

FINDINGS:

(1) Drainage Plan per DPM required.

(2) Ponding w/ controlled release required to public R/W or drainage easement.

RECEIVED
APR 16 1984
HYDROLOGY SECTION

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED:	[signature]	SIGNED:	[signature]
TITLE:	CE/Hydrology	TITLE:	Engineer
DATE:	12/19/83	DATE:	12/19/83

Additional Final Information

INFORMATION SHEET

Bldg Permit

PROJECT TITLE P.P.G. Industrial TYPE OF SUBMITTAL Final Drawing

ZONE ATLAS PAGE NO. G16 CITY ADDRESS 2200 Candelaria Rd. NE

LEGAL DESCRIPTION Parcel 4 - Hahn Parcel

ENGINEERING FIRM A & E Engr. Inc CONTACT John F Esquivel

ADDRESS 1330 San Pedro NE PHONE 266-8791

OWNER P.P.G. Industrial CONTACT Don Powell

ADDRESS 2906 Broadway NE PHONE 345-8591

ARCHITECT Engr. Associates CONTACT Jim Innis

ADDRESS 1840 Lomas Blvd. PHONE 247-7522

SURVEYOR A & E Engr. Inc CONTACT John F Esquivel

ADDRESS PHONE 266 8791

CONTRACTOR Jaynes Corp. CONTACT Don Johnson

ADDRESS 2906 Broadway NE PHONE 345 8591

PRE-DESIGN MEETING:

✓ YES
___ NO
X ~~COPY~~ OF CONFERENCE RECAP SHEET PROVIDED

PLEASE CHECK TYPE OF APPROVAL EXPECTED WITH THIS SUBMITTAL:

___ SKETCH PLAT APPROVAL
___ PRELIMINARY PLAT APPROVAL
___ SITE DEVELOPMENT PLAN APPROVAL
___ FINAL PLAT APPROVAL
X BUILDING PERMIT APPROVAL
___ CERTIFICATE OF OCCUPANCY APPROVAL
___ ROUGH GRADING PERMIT APPROVAL
___ GRADING/PAVING PERMIT APPROVAL
___ OTHER _____ (SPECIFY)

DATE SUBMITTED: 4/16/84

BY: John Esq

Final Additional Information

RECEIVED
APR 16 1984
HYDROLOGY SECTION

John Armstrong

City of Albuquerque
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION
123 Central NW, Albuquerque, NM 87102
(505) 766-7644

April 17, 1984

Mr. John F. Esquibel
A & E Engineering
1330 San Pedro NE, Suite 101
Albuquerque, NM 87110

REF: PPG DRAINAGE PLAN (G16-D50)

Dear Mr. Esquibel:

The above mentioned drainage plan, as revised 4/16/84, is hereby approved.

If you have any questions, please feel free to call me at 766-7644.

Thank you,

John Armstrong
Civil Engineer/Hydrology

JA:mrk