

## City of Albuquerque Stormwater Construction Site Inspection Report

General Information							
Project Name:		MJ Hospitality	y Self Storage				
Location:		1400 Yale					
Site Contact Name &		Leo Rojas - ARFA Const. ESC File No.			G16E095F		
Agency		jasser007@g		NPDES Id. No.		NMR1000YT	
Inspection Date:				025/1046hrs			
	water Inspecto	r: T	imothy E. Sims		2 1 (1		
	ction Phase:		le: = .1		2nd floor	Ta44/0 1 : .	le n
Type of ir	rspection:	Regular	Storm Event	Post Storm E	vent >0.25	311/Complaint	x Follow Up
Weath	er at time of i	ncnection?	Cla	ar	Tompo	raturo: ~	45*
Fstimated	date of last s	nspection? Clear torm 0.25" or greater			Temperature: ~ 45* 11/27/2019		
	date of last's	0.25	n greater			11/27/2013	
Item	Deficiency/ Corrective Action						
Number							
1	Please mitigate west side of sites BMP. (either reinstall silt fence per plan detail or provide an						
	equal BMP such as a mulch sock along western construction fence line)						
2	concrete washout facility requires maintenance. Please mitigate.						
3	Required reporting for an storm event is manditory after 0.25" of precipitation. On 11/27/2019						
	an event occurred. Provide SWPPP self-inspection report.						
2.1	Discharge off site?	(Y/N)	No				
4	Self Inspec	tion Reports	requested	Latest rep	ort Date:	11/8/	2019
				_			
Notes:							

 ${\bf City\ of\ Albuquerque\ Stormwater\ Inspector\ Signature\ and\ date:}$ 

Contact information: Timothy E. Sims - (505) 803-6155

<u>tsims@cabq.gov</u> 12/03/19