

City of Albuquerque Stormwater Construction Site Inspection Report

General Information

Project Name:	MJ Hospitality Self Storage						
Location:	4100 Yale						
Site Contact Name & Agency	Leo Rojas - ARFA Const.		ESC File No.		G16E095F		
	jasser007@gmail.com		NPDES Id. No.		NMR1000YT		
Inspection Date:	11/08/19	Start/End Time:		10:15/10:25AM			
CoA Stormwater Inspector:	Doug Hughes						
Construction Phase:	Vertical						
Type of Inspection:	Regular	Storm Event	Post Storm Event >0.25"	311/Complaint	Follow Up		

Weather at time of inspection?	clear	Temperature: ~	55
Estimated date of last storm 0.25" or greater	11/6/2019		

Item Number	Deficiency/ Corrective Action			
1	Concrete wash water in dirt next to lined pit needs removed. Pit needs maintenance.			
2	Selt fence on west side of site not toed in and has holes. Maintenance required.			
2.1	Discharge off site? (Y/N)	Yes		
3	Self Inspection Reports		Latest report Date:	9/18/2019

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:

Contact information: Doug Hughes (505) 924-3420

jhughes@cabq.gov

Doug Hughes 11/12/2019