




MJ Hospitality LLC Self Storage
MJ Hospitality, LLC.
General Permit SWPPP Inspection

 4100 YALE BLVD NE
ALBUQUERQUE, NM
87107



Last Rain Event

Wednesday, March 24, 2021,
0.03"

Last Precipitation

Thursday, March 25, 2021,
0.03"

48h
Forecast

--

Inspection Date and Time
Mar 26, 2021, 10:24:07 AM

Completed by
Marcos Valadez

Frequency
Bi-weekly -

Permit #
G16E095F NMR1000YU NMR1000YT

Inspection Form Instructions - Review each question for this inspection carefully, then answer YES, NO, or N/A (not applicable). If any of the items below are out of compliance, press the "Add Action Item" button above to add a corrective action.

General
Information

Inspector's Qualifications - Trained and work experience - see inspector qualification page in section 2 of the SWPPP.

Type of Inspection:

Regular

~~During storm-
event~~

~~Post storm event~~

Weather
Information

Last Storm Event Information - For information on the last storm event, see the weather event information at the end of this inspection.

Weather at time of this inspection?

~~Clear~~

~~Cloudy~~

~~Rain~~

~~Sleet~~

~~Snowing~~

~~High Winds~~

**Partly
Cloudy**

Have any discharges occurred since the last inspection?

~~Yes~~

No

If yes, what did the water look like at the time of the discharge?

Are there any discharges at the time of this inspection?

~~Yes~~

No

If yes, what did the water look like at the time of the discharge?

Is a rain gauge installed on site?

~~Yes~~

No

If yes, where is it located?

Has the Rain Event Page been filled out?

~~Yes~~

No

Are there SDS sheets on site?

~~Yes~~

No

If yes, where are they located?

If construction ceases on the site for more than 14 days, the site must be stabilized until construction resumes.

Date Construction Stopped

Date Construction Resumed

Measures Taken to Stabilize the Site:

Construction
Phasing

Verify what stage of construction the project is in, and record dates when activities started and were completed.

Installed BMPs

~~Not Started~~

~~Started~~

Completed

Started:

Completed:

Site Clearing and Grading

~~Not Started~~

~~Started~~

| **Completed**

Started:

Completed:

Installing Utilities

~~Not Started~~

~~Started~~

| **Completed**

Started:

Completed:

Building Structure

~~Not Started~~

~~Started~~

| **Completed**

Started: 01/18/19

Completed: 01/29/21

Paving and Walks

~~Not Started~~

~~Started~~

| **Completed**

Started:

Completed:

Final Grading/Stabilize Site

~~Not Started~~

~~Started~~

| **Completed**

Started: 01/14/21

Completed: 01/29/21

Other

Started:

Site-specific BMPs

The corrective actions initiated and date completed are in the Corrective Action Log

List of BMPs Installed:

BMP's have been removed except Portable Toilet

Are all of the above controls installed?

☒ **Yes**
☐ ~~No~~

Do any of the above controls need maintenance?

☐ ~~Yes~~
☒ **No**

If any of the controls have not been installed or require maintenance, please list the control and explain.

Are the BMPs shown on the map?

☒ **Yes**
☐ ~~No~~

Were there any changes to the SWPPP?

☐ ~~Yes~~
☒ **No**

Has the SWPPP been updated?

☐ ~~Yes~~
☒ **No**

Were the changes to the SWPPP implemented within 7 days?

☒ **Yes**
☐ ~~No~~

List any new BMPs needed:

Notes:

The site is 100% stabilized with paving, concrete and gravel. (looks great)

Oversight Issues

A list of corrective actions will be supplied with this inspection.

1. Are all slopes and disturbed areas not actively being worked properly stabilized?

Implemented?

~~Yes~~

~~No~~

| **N/A**

Maintenance Required?

~~Yes~~

~~No~~

| **N/A**

2. Are natural resources (e.g., streams, Arroyos, mature trees, etc.) protected with barriers or similar BMPs?

Implemented?

| **Yes**

~~No~~

~~N/A~~

Maintenance Required?

~~Yes~~

| **No**

~~N/A~~

3. Are perimeter controls and sediment barriers adequately installed (keyed into substrate) and maintained?

Implemented?

~~Yes~~

~~No~~

| **N/A**

Maintenance Required?

~~Yes~~

~~No~~

| **N/A**

4. Are discharge points and receiving waters free of any sediment deposits?

Implemented?

| **Yes**
~~No~~
~~N/A~~

Maintenance Required?

~~Yes~~
| **No**
~~N/A~~

5. Are storm drain inlets properly protected?

Implemented?

~~Yes~~
~~No~~
| **N/A**

Maintenance Required?

~~Yes~~
~~No~~
| **N/A**

6. Is the construction exit preventing sediment from being tracked into the street?

Implemented?

~~Yes~~
~~No~~
| **N/A**

Maintenance Required?

~~Yes~~
~~No~~
| **N/A**

7. Is trash/litter from work areas collected and placed in dumpsters?

Implemented?

~~Yes~~
~~No~~
| **N/A**

Maintenance Required?

~~Yes~~
~~No~~

| **N/A**

8. Are washout facilities (e.g., paint, stucco, concrete) available, clearly marked, and maintained?

Implemented?

~~Yes~~

~~No~~

| **N/A**

Maintenance Required?

~~Yes~~

~~No~~

| **N/A**

9. Are vehicle and equipment fueling, cleaning, and maintenance areas free of spills, leaks, or any other deleterious material?

Implemented?

~~Yes~~

~~No~~

| **N/A**

Maintenance Required

~~Yes~~

~~No~~

| **N/A**

10. Are materials that are potential storm water contaminants stored inside or under cover?

Implemented?

~~Yes~~

~~No~~

| **N/A**

Maintenance Required?

~~Yes~~

~~No~~

| **N/A**

11. Are non-storm water discharges (e.g., wash water, dewatering) properly controlled?

Implemented?

~~Yes~~

~~No~~

|

| **N/A**

Maintenance Required?

~~Yes~~

~~No~~

| **N/A**

12. Has the Site map been updated to reflect current conditions?

Implemented?

| **Yes**

~~No~~

~~N/A~~

Maintenance Required?

~~Yes~~

| **No**

~~N/A~~

13. Is the NOI posted?

Implemented?

~~Yes~~

| **No**

~~N/A~~

Maintenance Required?

| **Yes**

~~No~~

~~N/A~~

14. Were previous corrections made within 7 days of last inspection or before the next storm event?

Implemented?

~~Yes~~

~~No~~

| **N/A**

Maintenance Required?

~~Yes~~

~~No~~

| **N/A**

Walk through facility and look for signs of pollution including paint, solvents, chemicals, solid

waste, oil, and fuel.

Are there any signs of hazardous materials being exposed to storm water runoff?

~~Yes~~

☒ **No**

Have there been any reportable quantities releases of hazardous materials?

~~Yes~~

☒ **No**

Additional Notes

The C.O certificate of occupancy is required by city of Albuquerque to file the N O T (notice of termination)

Certification

Certification Statement:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Electronic Signature

X *Marcos Valadez*

Date

March 26, 2021 at 10:26:29 AM MDT

Title

Inspector

Weather History

☒ Precipitation Recorded ☐ No Precipitation ☐ Missed or data unavailable

March

12 th	0	13 th	0	14 th	0	15 th	0	16 th	0.08"	17 th	0	18 th	0
19 th	0	20 th	0	21 st	0	22 nd	0	23 rd	0.24"	24 th	0.03"	25 th	0
26 th	0												

All precipitation totals are obtained from the National Oceanic and Atmospheric Administration (NOAA). Precipitation readings are based on the latitude and longitude for each site as entered into complianceGO. Occasionally NOAA fails to return/record data. Days where this occurs are so indicated.

There Are No Action Items