


CITY OF ALBUQUERQUE



December 9, 2019

Jozy Tosta
Jozy Tosta Construction
3301 Candelaria Road NE
Albuquerque, NM

Re: Project Name
3301 Candelaria Road NE
Traffic Circulation Layout
Engineer's/Architect's Stamp 08-21-2019 (G16D097)

Dear Mr. Tosta,

Based upon the information provided in your submittal received 12-05-2019, the above referenced plan cannot be approved for Building Permit until the following comments are addressed:

1. Per DPM, a 6 ft. wide ADA accessible pedestrian pathway is required from the ADA parking stall access aisles to the building entrances. Please clearly show this pathway and provide details.

PO Box 1293

Once corrections are complete resubmit

Albuquerque

1. The Traffic Circulation Layout
2. A Drainage Transportation Information Sheet (DTIS)
3. Send an electronic copy of your submittal to PLNDRS@cabq.gov.
4. No fee! The fee is waived by the engineer.

NM 87103

for log in and evaluation by Transportation.

www.cabq.gov

If you have any questions, please contact me at (505) 924-3675.

Mojgan Maadandar, E.I.
Associate Engineer, Planning Dept.
Development Review Services

\MM via: email
C: CO Clerk, File