

Elliott, Stanice

From: Elliott, Stanice
Sent: Thursday, December 22, 2016 9:17 AM
To: 'David Soule'
Subject: Coles Metal
Attachments: IMG_2012.JPG

David

This email is being sent in lieu of an attached comment letter in order to expedite the response for initial reviews. Responses to comments should continue to be included in the re-submittal. A reply to this email with responses to comments will not be considered a re-submittal.

Based upon the information provided in your submittal received 12-19-2016, the above referenced plan cannot be approved for PERM CO until the following comments are addressed:

- There appears to be an outfall on the property. Pipe needs grate on top. As-built does not indicate where it flows. See attached pic.
- End of 4" pipe at NW corner in pond is covered. Unable to see.

If you have any question please do not hesitate to contact me.

Stanice 'Totten' Elliott
Planning Department
Hydrology Section
City of Albuquerque
505-924-3982
505-924-3864 fax