



# City of Albuquerque Stormwater Construction Site Inspection Report

## General Information

ESC File No.	G17E021	Project Name:	Raising Canes #852		
NPDES Id. No.	NMR1004EV	Location:	4800 Montgomery		
8/12/2022	Owner	Contractor			
Operator	Raising Cane's Restaurants, LLC		Guzman		
Contact name & title	Robert Montgomery				
e-mail	<a href="mailto:shawnp@lowesmarket.com">shawnp@lowesmarket.com</a>				
Contact Phone #	806-786-0255				
COA Inspector	Doug Hughes		Start/End Time:	11:50am	
Construction Phase:	Staging				
Type of Inspection:	<input checked="" type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Past Storm Event >0.25"	<input type="checkbox"/> 311/Complaint	<input type="checkbox"/> Follow Up
Weather at time of inspection?		Clear		Temperature: ~	80
Estimated date of last storm 0.25" or greater		8/1/2022			

Item Number	Deficiency/ Corrective Action				
1	NPDES Permit wasn't posted for safe public viewing. Post sign per CGP 1.5.				
2	The SWPPP wasn't available on site. Keep up-to-date SWPPP available on site. CGP 7.1				
3	BMPs were missing. Construct BMPs per approved details in 7 days or less. CGP 5				
4	Building was demolished and waste covered half of the site. 13. Dispose of construction and domestic waste in acceptable containers daily and use lids or tarps to cover waste containers when not in use per CGP 2.3.3.e				
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	required	Latest report Date:	none	

Notes:	The construction trailer was open but crew couldn't find SI or SWPPP.

City of Albuquerque Stormwater Inspector Signature and date:  
Contact information: Doug Hughes (505-924-3420)  
[jhughes@cabq.gov](mailto:jhughes@cabq.gov)

8/12/2022  
James D. Hughes