



Alan Varela, Director

May 16, 2022

Lauren Nuffer PE Kimley-Horn and Associates Inc. 13455 Noel Rd. Suite 700 Dallas TX 75240

Re: Raising Cane's 4800 Montgomery Blvd. NE

Erosion and Sediment Control Plan

Engineer's Stamp Date 5/12/22 (G17E011)

Dear Mr. Nuffer,

Based upon the information provided in your submittal received on 5/12/22, the above referenced ESC Plan can't be approved until the following comments have been addressed.

- 1. The existing and proposed grades and storm drains must be shown on the ESC Plan, and they must agree with the Grading Plan approved by Hydrology (CGP7.2.4.b.ii);
- 2. The limits of disturbance must include all frontage improvements (CGP7.2.4.b.i);
- 3. Describe the Work Order construction in the Schedule and Phasing and add BMPs for that phase of the work.
- 4. Update the engineer's stamp date each time the plan is changed.

If you have any questions, you can contact me at 924-3420 or jhughes@cabq.gov.

Sincerely,

James D. Hughes

James D. Hughes, P.E. Principal Engineer, Planning Dept. Development and Review Services