

## MEMORANDUM

To: James D. Hughes, P.E.  
Principal Engineer, Planning Dept  
Development and Review Services  
City of Albuquerque

From: Liz Willmot, P.E.  
Civil Project Manager  
Kimley-Horn

Date: May 12, 2022

Subject: **Raising Cane's 4800 Montgomery Blvd. NE**  
Erosion and Sediment Control Plan  
*Engineer's Stamp Date 4/4/2022 (G17E011)*

---

## Overview

The intent of this memo is to provide responses to Correction Notice #1 of the Project Raising Cane's 4800 Montgomery Blvd. NE, submitted to One Albuquerque Planning. Please find the corrections listed below with our response to corrections in **bold**.

## Response to Corrections

1. The ESC Plan can't be approved until after Hydrology approves the G&D Plan. The existing and proposed grades and storm drains must be shown on the ESC Plan and they must agree with the Grading Plan approved by Hydrology (CGP7.2.4.b.ii);

**Hydrology has approved the G&D plan, a copy of the approval has been included with this resubmittal.**

2. The 2017 CGP doesn't cover sites where construction activities commence on or after 2/17/2022. The SWPPP and NOI must be updated to the 2022 CGP per Part 1.4.3

**The SWPPP and NOI have been updated per the 2022 CGP, Part 1.4.3.**

3. The SWPPP must include site-specific interim and permanent stabilization per CGP 9.4.1.c.i. The Landscape Plan and Work Order sheets can be used to satisfy this requirement and should be submitted separate from the ESC Plan with the application to the Stormwater Quality Section of the Planning Department and they should be included in the SWPPP.

**The SWPPP has been updated accordingly.**

4. Identify stormwater team members (CGP 6.1 and 7.2.2):
  - a. Personnel who are responsible for the design, installation, maintenance, and/or repair of stormwater controls (including pollution prevention controls);
  - b. Personnel responsible for the application and storage of treatment chemicals (if applicable);
  - c. Personnel who are responsible for conducting inspections as required in Part 7.2.21: and
  - d. Personnel who are responsible for taking corrective actions as required in Part 5. Include name, phone #, and email address.

**The SWPPP has been updated accordingly.**

5. Update engineer's stamp date each time the plan is changed

**The Engineer's stamp date has been updated. See civil sheets for update.**