CITY OF ALBUQUERQUE

Planning Department Brennon Williams, Director



Mayor Timothy M. Keller

January 26, 2021


Matthew Kuehn 277 E. Camelback Road Suite 325 Phoenix, AZ

Re: 3801 Paseo del Norte (C17D129)

Dear Mr. Kuehn:

Based upon the information provided in your submittal received 1-22-2021, the above referenced plan cannot be approved for a construction permit until the following comments are addressed:

- 1. Provide narrative of project on the TCL, explaining its use for private purposes only.
- 2. The current cul-de-sac diameter does not meet current standards for a turnaround. Please see attached options which may result in the need to dedicate an additional roadway easement area:



www.cabq.gov

PO Box 1293

- 3. Provide a turning template design which can demonstrate that the existing access width into the property is sufficient.
- 4. All properties are required to have sidewalk along the perimeter of the property per ordinance. In this case, you may submit a sidewalk waiver request for our records.
- 5. Identify whether this is a paved or gravel parking lot surface.
- 6. Identify any parking lot striping or parking bumpers with additional notes.
- 7. Protect light poles in the center of the site with curb placement, and provide a curb detail. Curb should be 6" to 8" high.

CITY OF ALBUQUERQUE

Planning Department Brennon Williams, Director



Once corrections are complete resubmit the following for further evaluation by Transportation:

- 1. The Traffic Circulation Layout
- 2. A Drainage Transportation Information Sheet (DTIS)
- 3. Send an electronic copy of your submittal to PLNDRS@cabq.gov.
- 4. The \$75 re-submittal fee.

If you have any questions, please contact me at (505) 924-3991.

Sincerely,

Jeanne wolfenbarger

PO Box 1293 Jeanne Wolfenbarger, P.E. Traffic Engineer, Planning Dept. Development Review Services

Albuquerque

| | via: email |
|--------|----------------|
| C: | CO Clerk, File |

NM 87103

www.cabq.gov