

## City of Albuquerque Stormwater Construction Site Inspection Report

## General Information

Project Name:	La Mirada Townhomes				
Location:	Wyoming and La Mirada				
Site Contact Name & Agency	James Seligman	ESC File No.	G19E038A		
	Owner	NPDES Id. No.			
Inspection Date:	06/10/19	Start/End Time:	8:30	8:40	
CoA Stormwater Inspector:	Curtis Cherne				
Construction Phase:	East units mostly complete				
Type of Inspection:	<input type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Post Storm Event >0.25"	<input type="checkbox"/> 311/Complaint	<input checked="" type="checkbox"/> Follow Up

Weather at time of inspection?	Cloudy	Temperature	60
Estimated date of last storm 0.25" or greater	5/10/2019		

Item Number	Deficiency/ Corrective Action			
1	sediment in gutter and street			
2	no sediment BMP to prevent dirt form entering street			
3	wash-out in the dirt			
4	no acceptable wash-out facility on-site			
5	SWPPP self-inspection report was requested on 5-29-19 and has not been received			
2.1	Discharge off site? (Y/N)	No		
4	Self Inspection Reports	request	Latest report Date:	?

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:

Contact information: Curtis Cherne PE, 505-924-3420

[ccherne@cabq.gov](mailto:ccherne@cabq.gov)

06/10/19

Auto G Chem