

**Review Comments**  
**Chase Bank ATM**  
**11004 Montgomery Blvd NE**  
**Traffic Circulation Layout**  
**Engineer's Stamp 07-02-2021 (G21-D018A(A))**

---

1. List the number of parking spaces required by the IDO as well as the proposed number of parking spaces including bicycle and motorcycle parking. Coordinate/discuss with Zoning with the calculations listed on site plan to substantiate the removal of parking stalls to construction ATM infrastructure.  
**Response: Parking requirements table added to plans.**
2. Please provide the initial submittal fee receipt for this ATM project.  
**Response: Receipt added to submittal**
3. You are referencing details but no sheet is referenced for the detail. Reference sheet C1.03 all referenced details.  
**Response: Details referenced to details sheet.**
4. Provide a bollard detail proposed on sheet C1.02.  
**Response: Bollard detail added to sheet C1.02 and note to paint bollard yellow.**
5. All proposed striping will need details (stripe color, thickness & spacing between stripes).  
**Response: Striping details added to details sheet.**
6. Any safety concern with free standing NO TRESPASSING sign without curbing on the departure of ATM. Please address this concern.  
**Response: No trespassing sign removed from the departure area of the ATM.**
7. You have a symbol that appears to be light pole but no detail. Provide detail.  
**Response: Light pole details added to sheet C1.04**
8. Any problems with stacking over flow interfering with existing parking stalls and drive aisle? Please address.  
**Response: Vehicle stacking increased to 3 cars 10'x20'.**
9. Please provide a letter of response for all comments given.  
**Response: Response Letter to city comments provided.**