

CITY OF ALBUQUERQUE



May 15, 2019

The Design Group
Dave Aube
120 Vassar Drive NE
Albuquerque, NM

Re: **GAHP INCA**
3701,3705, and 3711 Inca St. NE
Traffic Circulation Layout
Engineer's/Architect's Stamp **05-13-19** (G21D044)

Dear Mr.Aube,

1. The handicap accessible spaces must include an access aisle. Van accessible aisles should be 8ft wide; all others should be 5ft wide. Also needs to be striped.
2. The ADA access aisles shall have the words "**NO PARKING**" in capital letters, each of which shall be at least one foot high and at least two inches wide, placed at the rear of the parking space so as to be close to where an adjacent vehicle's rear tire would be placed. (66-1-4.1.B NMSA 1978)
3. Please remove the asphalt removing section "10" from TCL. That part requires a mini work order.
4. For keyed note # 8 please use NMDOT standard.

Resubmit a revised plan along with fully completed DTIS to front counter personnel for log in and evaluation by Transportation. PDF copies of the plans and submittal package must be emailed to PLNDRS@cabq.gov at time of resubmittal. If you have any questions, please contact me at 924-3675.

Sincerely,

Mojgan Maadandar, E.I.
Associate Engineer, Planning Dept.
Development Review Services

/MM via: email
C: CO Clerk, File