

# CITY OF ALBUQUERQUE



August 9, 2013

Karen G. Perez, P.E.  
Wilson & Company, Inc.  
4900 Lang Ave. NE  
Albuquerque, NM 87109

**Re: El Dorado High School  
Drainage Master Plan (G22/D004)  
Engineer's Stamp Date N/A**

Dear Ms. Perez,

Based upon the information provided in your submittal received 7-10-13, we offer the following comments:

- Are there any offsite runoff entering the site? Is there adequate water block at the entrances?
- What is the land treatment for Basin 112/212? This basin was not included in the AHYMO calculations.
- Please provide large size maps including the basin table, analysis point, and storm drain structures.
- The legend under Figure 8 does not include all the improvements shown on the map and Section 4.5. We recommend that 2013/2015 improvements and future improvement to be shown on two different maps.
- Please provide engineer's stamp on the report and the plans.

PO Box 1293

Albuquerque

New Mexico 87103

If you have any questions, you can contact me at 924-3695.

[www.cabq.gov](http://www.cabq.gov)

Sincerely,

Shahab Biazar, P.E.  
Senior Engineer, Planning Dept.  
Development and Building Services

C: e-mail