



Alan Varela, Director

July 8, 2024

Cassandra Durkin, CPESC
BBA Stormwater Services & More, LLC.
7625 Vista Del Arroyo Ave. NE
Albuquerque, NM 87109

**Re: Lobos Logistics, LLC at 7850 La Morada Pl. NW
Erosion and Sediment Control Plan
Engineer's Stamp Date 7/1/24 (H09E001B)**

Ms. Durkin,

Based on the information provided in your submittal, received on 7/3/24, the above-referenced ESC Plan and NOI have been reviewed and approved by the Stormwater Quality Section of the city Planning Department for Grading Permit, and for inclusion in the SWPPP. Grading Permits and Paving permits must be obtained separately from the Hydrology Section of the city Planning Department.

The operator must ensure that the following personnel on the stormwater team understand the requirements of this permit and their specific responsibilities with respect to those requirements:

- a. Personnel who are responsible for the design, installation, Maintenance, and/or repair of stormwater controls (including pollution prevention controls);
- b. Personnel responsible for the application and storage of treatment chemicals (if applicable);
- c. Personnel who are responsible for conducting inspections as required in Part 4.1; and
- d. Personnel who are responsible for taking corrective actions as required in Part 5.

You must also post your notice of CGP coverage per Part 1.5 and install the BMP controls.

In accordance with City Ordinance 14-5-2-11(C)(1), self-inspections must continue until the site is "determined as stabilized by the city." The property owner/operator is responsible for determining when the "Conditions for Terminating Coverage" per CGP Part 8.2 are satisfied and then for filing their Notice of Termination (NOT) with the EPA. Each operator may terminate CGP coverage only if one or more of the conditions in Part 8.2.1, 8.2.2, or 8.2.3 has occurred. After filing the NOT with the EPA, the property owner is responsible for requesting a Determination of Stabilization with the City.

If you have any questions, contact me at 924-3420 or jhughes@cabq.gov.

Sincerely,

A handwritten signature in black ink that reads "James D. Hughes".

James D. Hughes, P.E.
Principal Engineer, Planning Dept.
Development and Review Services



Mayor Timothy M. Keller