

# CITY OF ALBUQUERQUE



March 20, 2014

Brian Patterson, P.E.  
Bohannon Huston Inc.  
7500 Jefferson NE  
Albuquerque, NM 87107

**Re: Pulte@ Mirehaven Phase 1 Grading Plan**  
**Engineer's Stamp Date Sheet 1: 12-19-13, Sheet 2: 3-12-14, Sheet 3: 3-12-14,**  
**Sheet 4: 12-19-13, Sheet 5: 1-23-14, Sheet 6: 1-23-14 (H09D017B)**

Dear Mr. Patterson,

Based upon the information provided in your submittal received 12-20-13, 3-3-14 and 3-12-14 the above referenced plan meets the requirements for Grading Permit. The site is approved for Grading Permit when the Erosion and Sediment Control Plan is approved.

If the stamp dates on the sheets mentioned above are incorrect, please let me know.

The angled horizontal alignment of the storm drain shown on Sheet 2 is subject to approval at DRC.

The high point in the open space between Lots 36 and 37 as shown on Sheet 5 is expected to be followed on Sheet 6, where it is not shown.

If you have any questions or would like to meet, you can contact me at 924-3986.

Sincerely,

Curtis Cherne, P.E.  
Principal Engineer, Hydrology  
Planning Dept.

C: e-mail - Brian Patterson, P.E., Kevin Patton, P.E., Shahab Biazar, P.E.