

CITY OF ALBUQUERQUE



March 28, 2014

Mr. Michael D. Tull, P.E.
Superior Storm Water Services, LLC
8505 Paseo Alameda
Albuquerque, New Mexico 87113

**Re: Pulte @ Mirehaven Phase I
Erosion Sediment Control (ESC) Plan
Engineer's Stamp Date 3/18/2014 Sheet 1 of 3 And Engineer's Stamp Date
3/17/2014 Sheets 2 of 3 & 3 of 3 (H09/E017B)**

Dear Mr. Patterson,

Based upon your submittal received 3-18-14, the above referenced Erosion Sediment Control (ESC) plan is acceptable for Grading and Work Order based on the following condition:

_ NPDES Posting Board should be visible from public sidewalk or street.

This project requires a National Pollutant Discharge Elimination System (NPDES) permit for storm water discharge for disturbing one acre or more and a Topsoil Disturbance Permit for disturbing $\frac{3}{4}$ of an acre or more.

If you have any questions, you can contact me at 924-3422.

Sincerely,

Shahab Biazar, P.E.
Principal Engineer Planning Dept.
Development Review Services

C: e-mail