

# CITY OF ALBUQUERQUE



October 10, 2014

Mr. Brian Patterson  
Bohannon-Huston, Inc.  
7500 Jefferson Street NE, Courtyard 1  
Albuquerque, NM 87109

**Re: Temporary Construction Entrance for Del Webb @ Mirehaven Phase I  
Grading and Drainage Plan  
Engineer's Stamp Date 10-7-14 (H09D017C)**

Dear Mr. Patterson,

Based upon the information provided in your submittal received October 7, 2014, the above referenced plan cannot be approved for Grading Permit until the following comments are addressed:

1. The temporary construction road and rock do not go all the way to Willow Canyon Trail. Please revise so that the temporary road is connected.
2. Extend the rip-rap more around the outlet of the proposed 24 inch CMPs.
3. Update the Erosion Control and Sediment Plan.

PO Box 1293

If you have any questions, you can contact me at 924-3994.

Sincerely,

Albuquerque

New Mexico 87103

Amy L. D. Niese, P.E.  
Senior Engineer, Hydrology  
Planning Department

[www.cabq.gov](http://www.cabq.gov)

C: e-mail