

CITY OF ALBUQUERQUE



August 7, 2015

Yolanda Padilla Moyer, P.E.
Bohannon Huston Inc.
7500 Jefferson St NE, Ctyd 1
Albuquerque, NM 87109

Re: Del Webb @ Mirehaven Phase 1
Pad Certification – Lots 47, 162-177
Conditional: Lots 166 through 169
Engineer's Stamp dated: 3-20-14, (H09D017C)
Certification dated: 7-27-15

Dear Ms. Padilla Moyer,

Based upon the information provided in the submittal received 7-28-15 and prudent line exhibit dated 8-7-15, the above referenced Certification is acceptable for Building Permit on the lots referenced above.

Since Lots 166 through 169 are partially shown on the arroyo side of the Prudent Line, the channel or southern half of the channel is to be constructed prior to obtaining Certificate of Occupancy.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality for Hydrology
Planning Dept.

C: File

