## CITY OF ALBUQUERQUE



March 21, 2016

David Tull, P.E. Superior Stormwater Services, LLC 8505 Paseo Alameda NE Albuquerque, NM 87113

Re: Del Webb @ Mirehaven Phase 2A Erosion Sediment Control Plan

Engineer's Stamp Date 2-12-16 (H09E017F)

Dear Mr. Tull,

Based upon the information provided in your submittal received 3-17-16 the above referenced plan is approved to be included in the SWPPP and for ESC Permit for grading and Building Permit with the condition that sediment BMPS be added, as necessary, in front yard swales on streets steeper than 2.5%.

The plan is also approved for Work Order. Please inform your client to include these sheets in the Work Order construction plans.

PO Box 1293

If you have any questions, you can contact me at 924-3420.

Albuquerque

New Mexico 87103

Sincerely,

Curtis Cherne, P.E.

Principal Engineer, Stormwater Quality

Planning Dept.

www.cabq.gov

C: Kevin Patton, Michael@superiorstormwater.com