City of Albuquerque Stormwater Construction Site Inspection Report

General Information

Project Name:	Del webb 3, 4		
Location:			
Site Contact Name & Agency	Brian Anderson / Pulte Group	ESC File No.	H09EV17G
		NPDES Id. No.	
Inspection Date:	5-7-19	Start/End Time:	10:00 / 10:50
CoA Stormwater Inspector:	Curtis Cherne		
Construction Phase:	infrastructure		
Type of Inspection:	Regular ☐ Storm Event ☐ Post Storm Event >0.25" ☐ 311/Complaint ☐ Follow Up ☒		

Weather at time of inspection? Cloudy	Temperature: ~65
Estimated date of last storm 0.25" or greater	4-22-19

Item Number	Deficiency/ Corrective Action
1	NO pond NW corner - small uncompacted berm
2	no pond or erosion control - north street and next st south
3.	no inlet protection at storm drain
4.	NO pond at storm drain location
5.	require silt fence SE corner
6.	re-establish gravel at staging area SE corner
2.1	Discharge off site? (Y/N) N
4	Self Inspection Reports — Latest report Date:

Notes:

Friday at 2 pm follow-up

City of Albuquerque Stormwater Inspector Signature and date: Curtis Cherne 5-7-19

Contact information: Curtis Cherne, 505-924-3420
ccherne@cabq.gov