



SWPPP COMPLIANCE INSPECTION REPORT

Date of Inspection: 9/14/2023

General Information - Section 1

Operator's Name: McDonald's USA, LLC
Project Name: Albuquerque, NM - Unser Blvd & Ladera Dr (30-0236)
Project Location: Albuquerque, NM
Type Of Inspection: Weekly

Conducted By: John Paiz
Title: Inspector
Contact Number: 5053193085

Weather Information - Section 2

Current Weather Conditions: **Partly Cloudy**

Weather on ground conditions: **Dry**

Has it rained since the last inspection? **Yes**

If Yes, what was the estimated total amount of rainfall? **Approximately 0.7 inch**

Stage of Construction - Section 3

Stage	Start Date Noted	Completion Date Noted	Notes
BMP Installation			
Demolition / Clearing			
Grading			
Installation of Drainage System			
Installation of Utilities	8/31/2023		
Paving			
Building Construction			
Landscaping / Site Stabilization			
Permanent BMPs			

Comments



SWPPP COMPLIANCE INSPECTION REPORT

Operator's Name: McDonald's USA, LLC
Project Name: Albuquerque, NM - Unser Blvd & Ladera Dr (30-0236)
Date: 9/14/2023

Conducted By: John Paiz
Title: Inspector
Contact Number: 5053193085

Overall Site Observation - Section 4

Areas Observed		Notes
Are perimeter BMPs adequate?	Yes	
Is inlet protection installed and maintained?	Yes	
Do structural BMPs need repair?	No	
Are additional structural BMPs needed?	No	
Are alternative structural BMPs needed?	No	
Do procedural BMPs need to be performed?	No	
Are perimeters free of off site tracking?	No	
Conditions at outfalls require corrective action?	No	
Are natural bodies of water protected?	Yes	
Is trash being contained?	Yes	
Does fuel cell have secondary containment?	Yes	
Is site free of leaks and spills?	Yes	
Are potential pollutants being stored properly?	Yes	
Is washout area clearly defined and maintained?	No	
Are non-storm water discharges being controlled?	Yes	
Are Site Notice(s) posted and legible?	Yes	
If SWPPP is on site are all documents present?	Yes	
Are changes necessary to the SWPPP?	No	

Certification

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. I further certify that I am familiar with the Federal Clean Water Act, EPA and state regulations regarding storm water inspections, the regulations themselves, and the SWPPP."

Signature:

Title: Inspector

Printed Name: John Paiz

Date: 9/14/2023



CORRECTIVE ACTION LOG

Operator's Name: McDonald's USA, LLC
Project Name: Albuquerque, NM - Unser Blvd & Ladera Dr (30-0236)
Project Location: Albuquerque, NM
Type Of Inspection: Weekly

Conducted By: John Paiz
Title: Inspector
Contact Number: 5053193085

Location	Corrective Actions Noted	Date Noted	Verified Repair Date
Main entrance	Street needs to be cleaned due to sediment track out	9/14/2023	
Perimeter around structure	Washout spoils need to be cleaned up off of ground.	9/14/2023	
Perimeter around structure	Washout spoils need to be cleaned up off of ground	9/7/2023	
Perimeter around structure	Washout spoils need to be cleaned up off of ground	8/31/2023	
Northwest corner, near structure and stockpile	Washout spoils need to be cleaned up off of ground	8/24/2023	
North corner perimeter	Repair or replace damaged silt fence	8/18/2023	
Concrete washout	Washout spoils need to be cleaned up off of ground.	9/7/2023	9/14/2023
Notes: Washout spoils have been cleaned			
Concrete washout	Washout facility needs to be sealed due to leaking	9/7/2023	9/14/2023
Notes: Washout facility has been lined with plastic			
Concrete washout	Washout spoils need to be cleaned up off of ground.	8/31/2023	9/14/2023
Notes: Washout spoils have been cleaned			
Concrete washout	Washout spoils need to be cleaned up off of ground.	8/24/2023	9/14/2023
Notes: Washout spoils have been cleaned			
Concrete washout	Washout spoils need to be cleaned up off of ground.	8/18/2023	9/14/2023
Notes: Washout spoils have been cleaned			