

City of Albuquerque Stormwater Construction Site Inspection Report

General Information									
Project Name:		Stormcloud Unit 4, The Ridge							
Location:		Tierra Pintada & mirehaven Arroyo							
Site Contact Name & Agency		Troy & Dan - Pulte			ESC File No.		H09E022A		
		troy.crutchfield2@pulte.com			NPDES Id. No.		NMT1000BY		
Inspection Date:		10/23/19		Start/End Time:		0745/0815hrs			
CoA Stormwater Inspector:				Timothy E. Sims					
Construction Phase:		home construction							
Type of Inspection:	x	Regular	Storm Event	Post Storm Event >0.25"	311/Complaint	Follow Up			

Weather at time of inspection?	Clear	Temperature: ~	44*
Estimated date of last storm 0.25" or greater	10/4/2019		

Item Number	Deficiency/ Corrective Action			
1	Washouts on the west side of White Squall. These washouts appear to be not related to Pulte's construction activities. However, mitigate these washouts.			
2	2001 White Squall requires a cut back behind drivepad cut out.			
3	8808 Wind Sock waste not in acceptable container.			
2.1	Discharge off site? (Y/N)	No		
4	Self Inspection Reports		Latest report Date:	10/4/2019

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Timothy E. Sims - (505) 803-6155
tsims@cabq.gov 10/23/19