

# CITY OF ALBUQUERQUE



June 15, 2017

David Soule, P.E.  
Inspections Plus Inc.  
4382 Alexander Blvd NE  
Albuquerque, NM 87107

**Re: Mirehaven Arroyo Improvements  
Erosion and Sediment Control Plan  
Engineer's Stamp Date 6-12-17 (H09E022A)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 6-12-17, the above referenced plan is for construction in an AMAFCA easement. Since AMAFCA is an MS4 co-permittee, AMAFCA would be the appropriate agency to review/approve this plan.

The city offers one informational comment:

PO Box 1293

1. Add a note to not stockpile dirt in the low-flow area of the channel.

Albuquerque

If you have any questions, you can contact me at 924-3420.

New Mexico 87103

Sincerely,

Curtis Cherne, P.E.  
Principal Engineer, Stormwater Quality  
Planning Dept.

[www.cabq.gov](http://www.cabq.gov)