



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	H09E022B	Project Name:	Stormcloud Unit 5		
NPDES Id. No.	NMR10012Y	Location:	Tierra Pintada and Torrent Dr.		
4/23/2021	Owner	Contractor			
Operator	DR Horton, Inc.				
Contact name & title	Kevin Griffin				
e-mail	ktgriffin@drhorton.com				
Contact Phone #	505-206-8226				
COA Inspector	Thomas Evans		Start/End Time:	8:45 AM/8:55 AM	
Construction Phase:	infrastructure				
Type of Inspection:	Regular	Storm Event	Past Storm Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection?	clear		Temperature:	~ 57	
Estimated date of last storm 0.25" or greater	2/22/2021				
Item Number	Deficiency/ Corrective Action				
1	Clean trackout				
2	Remove and dispose of washout. Do not pour washout on the ground.				
3	No posting of permit				
4					
5					
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	Requested	Latest report Date:		

Notes:	Six homes remaining.

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Thomas Evans (505-803-6215)
tevans@cabq.gov

Thomas Evans 04/23/2021