



Inspections Plus, Inc.

Engineer Stamp




4/25/17

Inspections Plus Inc.  
Erosion Control Plan  
Standard Details

Project:  
Stormcloud  
Subdivision Unit 5

### Stabilized Construction Entrance



#### Definition

A stabilized layer of aggregate that is underlain with Geotextile Class "C" (See Standards for Geotextiles). Stabilized entrances are located at any point where traffic enters or leaves a construction site.

#### Purpose

The purpose of the stabilized construction entrance is to reduce tracking of sediment onto streets or public right-of-way and provide a stable area for entrance or exit from the construction site.

#### Conditions where the Practice Applies

1. Stabilized construction entrances shall be located at points of construction ingress and egress.
2. For single family residences, the entrance should be located in the permanent driveway.
3. Stabilized construction entrances should not be used on existing pavement.

#### Design Criteria

1. Length - Minimum of 50'-0"
2. Width - Minimum of 30'-0", should be based on the existing road to provide a turning radius.
3. Geotextile Class "C" shall be placed over the existing ground prior to placing stone. The Plan approval authority may not require geotextile fabric for single family residences.
4. Stone-crushed aggregate 2" x 3/4" (See Standards for Geotextiles and Rock). Recycled concrete equivalents may be used also. The rock should be placed at least 6" deep over the length and width of the entrance.
5. Surface Water - All the surface water flowing to or diverted toward construction entrances shall be piped under the entrance to maintain positive drainage. Pipe installed under the construction entrance shall be protected with a manhole form. The pipe shall be sized according to the drainage, with the minimum diameter being 6".
6. Location - A stabilized construction entrance shall be located at every point where construction traffic enters or leaves a construction site. Vehicles leaving the site must travel over the entire length of the stabilized construction entrance.

10

### Inlet Filter Installation Instructions:




flow and starts filtering sediment and debris before water drops into the inlet.



3. Position the mat. Place Inlet Filter on grate with the net side down, flush to the back edge and extending beyond the grate opening on the front and both sides. The zip ties attach Inlet Filter to the inlet grate cover WITHOUT LIFTING THE GRATE COVER.

4. The filter material covering the inlet can be any material that will prevent the sediment and other foreign matter from entering the storm drain system.

### Silt Fence



#### Definition

A temporary barrier of Geotextile Class "F" used to intercept sediment laden runoff from small drainage areas.

#### Purpose

The purpose of silt fence is to reduce runoff volume velocity and allow the deposition of transported sediment to occur. Limits imposed by ultraviolet light on the stability of the fabric will dictate the maximum period that the silt fence may be used.

1. Silt fence provides a barrier that can collect and hold debris and soil, preventing the material from entering critical areas, streams, streets, etc.
2. Silt fence can be used where the installation of a ditch would destroy sensitive areas; wetlands, etc.

#### Conditions where the Practice Applies

Silt Fence is limited to intercepting short flow runoff from limited distances according to slope. It provides filtering and velocity dissipation to promote gravity settling of sediment.

#### Design Criteria

Wood or Steel Posts may be used in certain instances. Silt fence should be placed as close to the contour as possible. No section of silt fence should exceed a grade of 6 percent for a distance more than 50 feet. Where ends of the geotextile fabric come together, the ends shall be overlapped, folded, and stapled to prevent sediment bypass.

\* If wood posts are to be used they must meet the following specifications:

\* 1 1/2" x 1 1/2" minimum square posts or 1 1/2" minimum diameter round post

\* If metal posts are to be used they must be at least 1/2" or 1/4" post weighing not less than 1 lb. per linear foot.


The length of the flow contributing to silt fence shall conform to the following limitations.

Slope (%)	Flow Frequency	Size Length (%)	20' Post Length (ft)
2	0-500	Unlimited	Unlimited
2-10	501-1000	125	1,000
10-20	1001-1500	100	750
20-30	1501-2000	60	500
30-50	2001-2500	40	250
50+	>2500	20	125

4

### Concrete Washout Area

For use in High Water Table Areas



61

#### Definition

A temporary sediment trap formed by excavation behind the curb.

#### Purpose

The purpose is to intercept sediment laden runoff from the lot during construction and retain sediment on the lot.

#### Conditions where the Practice Applies

A cutback curb is installed when discharge from the lot runs over the curb.

#### Design Criteria


1. Cut back soil from behind curb 3 - 4' deep to form a temporary sediment trap.
2. Installing the sidewalk will form a two stage sediment trap that will be more effective.

24

### Curb Storm Inlet Protection with Wattles



### Curb Storm Drain Inlet Filter



Cross-Section

#### Definition

A filter constructed around a storm drain inlet.

#### Purpose

Storm drain inlet protection is used to filter sediment laden runoff before it enters the storm drain system.

#### Conditions where the Practice Applies

Storm drain inlet protection is a secondary sediment control device and is not to be used in place of a sediment trapping device unless approved by the appropriate approval authority.

#### Design Criteria

Storm drain inlet protection shall be used when the drainage area to an inlet is disturbed and the following conditions prevail:

1. It is not possible to temporarily divert the storm drain outfall into a sediment trapping device.
2. Watertight blocking of the inlets is not advisable.
3. Drainage area is less than 1/4 acre for curb or standard inlet protections and 1 acre for elevated or yard inlets. For yard inlets, the total for inlets in series must be 1 acre or less and the contributing drainage area must have slopes flatter than 5 percent. Maintenance requirements for storm drain inlet protection are intense, due to the susceptibility to clogging. When the structure does not drain completely within 24 hours after a storm event, it is clogged. When this occurs, accumulated sediment must be removed and the geotextile fabric or filtering device must be cleaned and replaced.

Several methods of covering inlets have been developed recently.

It is important to use methods that have been proven effective.

Follow local ordinances. Some communities do not allow covering

of storm inlets due to the possibility of increased flooding. Several


other important design considerations include traffic safety,

elimination of forage or the ends and underneath the filter cloth,

and prevention of the filter entering the inlet.

5

### Curb Storm Drain Inlet Protection



Cross-Section

#### Definition

A filter constructed around a storm drain inlet.

#### Purpose

Storm drain inlet protection is used to filter sediment laden runoff before it enters the storm drain system.

#### Conditions where the Practice Applies

Storm drain inlet protection is a secondary sediment control device and is not to be used in place of a sediment trapping device unless approved by the appropriate approval authority.

#### Design Criteria

Storm drain inlet protection shall be used when the drainage area to an inlet is disturbed and the following conditions prevail:

1. It is not possible to temporarily divert the storm drain outfall into a sediment trapping device.
2. Watertight blocking of the inlets is not advisable.
3. Drainage area is less than 1/4 acre for curb or standard inlet protections and 1 acre for elevated or yard inlets. For yard inlets, the total for inlets in series must be 1 acre or less and the contributing drainage area must have slopes flatter than 5 percent. Maintenance requirements for storm drain inlet protection are intense, due to the susceptibility to clogging. When the structure does not drain completely within 24 hours after a storm event, it is clogged. When this occurs, accumulated sediment must be removed and the geotextile fabric or filtering device must be cleaned and replaced.

Several methods of covering inlets have been developed recently.

It is important to use methods that have been proven effective.

Follow local ordinances. Some communities do not allow covering

of storm inlets due to the possibility of increased flooding. Several

other important design considerations include traffic safety,

elimination of forage or the ends and underneath the filter cloth,

and prevention of the filter entering the inlet.

6

### Erosion Control Notes

1. All perimeter erosion and sediment control measures shall be installed prior to the execution of any grading work and maintained by the grading contractor for the duration of the grading project. Failure to install and maintain erosion control is a violation of State Law and subject to fine.
2. The appropriate erosion control device(s) shall be installed prior to the inception of any land disturbing activity and shall be properly maintained for construction activities.
3. All Erosion Control devices and their installation shall meet the standards prescribed in the current guidelines for storm water management for construction activities.
4. Sediment collected behind the sediment filters and silt fences shall be removed when sediment reaches one third the height of the barrier.
5. Sediment filters and silt fences shall be inspected and maintained no less than weekly or within 24 hours of a rainfall event of 0.5 inches or more. Maintenance shall include but not be limited to sediment removal, barrier repair and / or replacement.
6. Construction Site Entrance: The contractor shall construct as a minimum one stabilized construction entrance at the location shown on the plans. If additional ingress and egress to the construction site is required, the contractor shall coordinate with the construction manager the location of these additional stabilized construction entrances. Usage of non-stabilized for ingress and egress will not be permitted. The stabilized entrances shall be maintained in a condition which will prevent tracking or flowing of sediment onto public right-of-way and paved driving lanes. This may require periodic top dressing with additional stone as conditions warrant. Repair of the entrances or cleaning of the right-of-way and paved driving lanes that have been soiled shall be performed by the contractor at his own expense satisfactory to the construction manager. When necessary, vehicle wheels and tires shall be cleaned to remove sediment prior to entering onto public right-of-way and public streets. When washing is required, it shall be done on an area stabilized with crushed stone.
7. The contractor shall at his own expense, periodically water the site to control dust.
8. Sedimentation and erosion control measures shall be removed following construction or upon permanent stabilization of the disturbed and graded areas, whichever occurs last.
9. All disturbed areas that are not to be paved shall be re-seeded unless noted otherwise.
10. The contractor shall keep the site clean at all times and control dust resulting from the earthwork operation. The contractor shall not track mud onto the public streets.