

CITY OF ALBUQUERQUE



October 14, 2014

Ms. Tandy Freel
Bohannon-Huston, Inc.
7500 Jefferson Street NE, Courtyard 1
Albuquerque, NM 87109

**Re: La Morada Substation
Conceptual Grading and Drainage Plan
No Engineer's Stamp (H10D006A4))**

Dear Ms. Freel,

Based upon the information provided in your submittal received September 30, 2014, the above referenced plan is approved for Site Development Plan for Building Permit action by the DRB.

When the Grading and Drainage Plan is submitted for Building Permit approval, please include the following:

1. Include a Zone Atlas Map on the plan with the site location noted. Include an Engineer's signed seal.
2. For existing flows, on-site and off-site basins were included. Maintain those basin areas when discussing the proposed flows and include land treatments A and C. Discuss the difference between existing and proposed flows. Also reference the Ladera Business Park Master Drainage Report which is allowing free discharge from this site.
3. Include an electronic copy of the plan and DTIS with all submittals.

PO Box 1293

Albuquerque

New Mexico 87103

www.cabq.gov

If you have any questions, you can contact me at 924-3994.

Sincerely,

Amy L. D. Niese, PE
Senior Engineer, Hydrology
Planning Department

C: e-mail