



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	H10E006A6	Project Name:	7501 La Morada Offices		
NPDES Id. No.	NMRI0070E	Location:	7501 La Morada		
2/19/2025	Owner	Contractor			
Operator	7501 La Morada LLC	All Seasons Roofing			
Contact name & title	Ted Jaramillo	Ted Jaramillo			
e-mail	ted@allseasonnm.com	ted@allseasonnm.com			
Contact Phone #	505-918-4111	505-918-4111			
COA Inspector	Chancellor English	Start/End Time:	230pm		
Construction Phase:	Grading				
Type of Inspection:	Regular	Storm Event	Post Storm Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection?	Clear		Temperature: ~	58	
Estimated date of last storm 0.25" or greater			11/7/2024		
Item Number	Deficiency/ Corrective Action				
1	SWPPP - The NOI was missing from the SWPPP in violation of CGP Part 7.2.11. Required mitigation: Once you are authorized for coverage under the CGP, you must include a copy of your NOI submitted to EPA along with any correspondence exchanged between you and EPA related to coverage per CGP Part 7.2.11.a.				
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	No	Latest report Date:	N/A	

Notes:	
All prior violations have been mitigated. Please ensure to include your signed inspection reports from your 3rd party inspectors.	

City of Albuquerque Stormwater Inspector Signature and date: 2/19/2025
Contact information: Chancellor English (505) 924-3325
cenglish@cabq.gov

Chancellor English