

CITY OF ALBUQUE

Planning Department
Brennon Williams, Director



Mayor Timothy M. Keller

July 30, 2020

Cassandra Durkin, CPESC, CESSWI
Inspections Plus Inc.
504 El Paraiso Rd. NE Suite B
Albuquerque, NM 87113

**Re: 2200 Vista Oriente NW
Erosion Sediment Control Plan
Engineer's Stamp Date 7/29/2020 (H10E032A)**

Dear Ms. Durkin,

Based upon the information provided in your submittal received 7/29/2020, the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit/eNOI for Grading and Building Permit.

The EPA Notice of Intent (NOI) documentation has been reviewed and signed by the City and is attached, so this project is approved for Grading.

If you have any questions, you can contact me at 924-3420 or jhughes@cabq.gov.

Sincerely,

James D. Hughes

James D. Hughes, P.E.
Principal Engineer, Planning Dept.
Development and Review Services