



# City of Albuquerque Stormwater Construction Site Inspection Report

## General Information

ESC File No.	H10E006A6	Project Name:			
NPDES Id. No.		Location:	7411 La Morada Pl. NW		
12/2/2021	Owner			Contractor	
Operator	United Concrete Co.				
Contact name & title	Isaac Rosas				
e-mail	<a href="mailto:joseisaac1983@gmail.com">joseisaac1983@gmail.com</a>				
Contact Phone #	(505)290-1339				
COA Inspector	James Hughes		Start/End Time:	11:30 AM - noon	
Construction Phase:	Building construction				
Type of Inspection:	Follow-up	Storm Event	Past Storm Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection?		clear		Temperature: ~	48
Estimated date of last storm 0.25" or greater		10/1/2021			
Item Number	Deficiency/ Corrective Action				
1	2 ac of land disturbing activities has occurred without an approved ESC Plan. Submit a complete ESC application including: ESC Plan, property owner's NOI, application form, and fees for review and approval.				
2	The NPDES permit coverage is not posted. Post the coverage for safe public viewing.				
3	Updated SWPPP not on site. Keep the updated SWPPP with inspection reports onsite and readily accessible.				
4	There aren't any BMPs onsite				
5	There are big piles of sediment in the street on both sides.				
6	There is concrete wash water in the dirt onsite. Pick up the washout and dispose with the waste. Direct wash water into lined containers.				
2.1	Discharge off site? (Y/N)	Yes			
4	SW{PPP	missing	Latest report Date:	N/A	

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:  
Contact information: James Hughes (505) 924-3942  
[Jhughes@cabq.gov](mailto:Jhughes@cabq.gov)

12/06/2021  
James D. Hughes