

CITY OF ALBUQUERQUE



November 15, 2016

Richard J. Berry, Mayor

Joe Cross, P.E.
Select Engineering Services
1544 N. Woodland Park Blvd
Layton, Utah 84041

RE: **Wienerschnitzel**
2551 Corona Dr. NW
Request 60-Day Temporary C.O. - Accepted
Engineer's Stamp Date 5-10-16 (File: H11D069)
Certification date: 11-10-16

Dear Mr. Cross:

Based upon the information provided in your submittal received 11/14/2016, the above referenced Certification received is acceptable for 60-day temporary release of Certificate of Occupancy by Hydrology.

- The 3' opening in curb to the retention pond has created a swale that is causing erosion. Recommend fractured rock be place from the curb to the center of the retention pond.
- The sidewalk culvert is missing

If you have any questions, you can contact me at 924-3986 or Totten Elliott at 924-3982.

Sincerely,

Abiel Carrillo, P.E.
Principal Engineer, Planning Dept.
Development Review Services

TE/AC

C: email, Cordova, Camille C.; Miranda, Rachel; Sandoval, Darlene M.; Blocker, Lois