CITY OF ALBUQUERQUE

Planning Department
Brennon Williams, Director



August 10, 2023


Ronald R. Bohannan, PE Tierra West, LLC 5571 Midway Park PI NE Albuquerque, NM 87109

Re: Playa Del Sur 99999 Miami Rd. NW Traffic Circulation Layout Engineer's Stamp XX-XX-XX (H11-D075)

Dear Mr. Bohannan,

Based upon the information provided in your submittal received 08-02-23, the above referenced plan cannot be approved for Building Permit until the following comments are addressed:

- 1. Show on the site plan the site accesses radiuses.
- 2. Engineer's stamped must be dated.
- 3. Show the clear sight triangle for both site acceses and add the following note to the plan: "Landscaping and signage will not interfere with clear sight requirements. Therefore, signs, walls, trees, and shrubbery between 3 and 8 feet tall (as measured from the gutter pan) will not be acceptable in the clear sight triangle.
- 4. Provide notes showing what work is included and on the work order and the private work on site.
- 5. Work within the public right of way requires a work order with DRC approved plans.
- 6. Please add a note on the plan stating "All improvements located in the Right of Way must be included on the work order."
- 7. Traffic Studies: See the Traffic Impact Study (TIS) thresholds. In general, a minimum combination of 100 vehicles entering and exiting in the peak hour warrants a Traffic Impact Study. Visit with Traffic Engineer for determination, and fill out a TIS Form that states whether one is warranted. In some cases, a trip generation may be requested for determination (Contact Matt Grush: mgrush@cabq.gov).
- 8. Please provide a copy of Solid Waste and Fire Marshal approval.
- 9. Please show on the site plan the status for the driveway for the highlighted lot.



PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

CITY OF ALBUQUERQUE

Planning Department
Brennon Williams, Director



1. Please provide a letter of response for all comments given.

Once corrections are complete resubmit

- 1. The Traffic Circulation Layout
- 2. A Drainage Transportation Information Sheet (DTIS)
- 3. Send an electronic copy of your submittal to PLNDRS@cabq.gov.
- 4. The \$75 re-submittal fee.

for log in and evaluation by Transportation.

If you have any questions, please contact me at (505) 924-3675.

Sincerely,

Marwa Al-najjar

PO Box 1293 Marwa Al-najjar

Associate Engineer, Planning Dept. Development Review Services

Albuquerque

NM 87103 \ma via: email

C: CO Clerk, File

www.cabq.gov




City of Albuquerque

Planning Department

Development & Building Services Division

DRAINAGE AND TRANSPORTATION INFORMATION SHEET

Project Title: Playa del Sur	Building Permit #	Hydrology File #	
DRB#_ Legal Description: THE N'LY PORTS OF TRS 3C ATRISCOGRANT & NE CORI TR COMPRISING POR TR 31	18 309 & 310 UNIT 8 TOWN OF VIET R 310 UNIT 8 & City Address 10 UNIT 8	OR Parcel 101105914924031608 101105913325731609 101105913424631610	
Applicant/Agent: Tierra West LLC Address: 5571 Midway Park Place N	E Phone: (50	05) 858-3100	
Email:			
Applicant/Owner:	Contact:		
Address:			
Email:			
TYPE OF DEVELOPMENT:PLA RE-SUBMITTAL:YES	T (#of lots)RESIDENCEDR NO	B SITE ADMIN SITE: X	
DEPARTMENT:TRANSPORT Check all that apply:	RTATION HYDROLOGY/	DRAINAGE	
TYPE OF SUBMITTAL:	TYPE OF APPROVA	L/ACCEPTANCE SOUGHT:	
ENGINEER/ARCHITECT CERTIFIC	CATIONBUILDING	BUILDING PERMIT APPROVAL	
PAD CERTIFICATION		CERTIFICATE OF OCCUPANCY	
CONCEPTUAL G&D PLAN	X CONCEPTU	XCONCEPTUAL TCL DRB APPROVAL	
GRADING PLAN	PRELIMINA	PRELIMINARY PLAT APPROVAL	
DRAINAGE REPORT	SITE PLAN	SITE PLAN FOR SUB'D APPROVAL	
DRAINAGE MASTER PLAN	SITE PLAN	SITE PLAN FOR BLDG PERMIT APPROVAL	
FLOOD PLAN DEVELOPMENT PE	RMIT APPFINAL PLA	FINAL PLAT APPROVAL	
ELEVATION CERTIFICATE	SIA/RELEAS	SIA/RELEASE OF FINANCIAL GUARANTEE	
CLOMR/LOMR		FOUNDATION PERMIT APPROVAL	
iggthereom TRAFFIC CIRCULATION LAYOUT	Γ (TCL)GRADING F	GRADING PERMIT APPROVAL	
ADMINISTRATIVE	SO-19 APPR	SO-19 APPROVAL	
TRAFFIC CIRCULATION LAYOUT	T FOR DRBPAVING PE	PAVING PERMIT APPROVAL	
APPROVAL	GRADING F	GRADING PAD CERTIFICATION	
TRAFFIC IMPACT STUDY (TIS)	WORK ORD	WORK ORDER APPROVAL	
STREET LIGHT LAYOUT	CLOMR/LO	MR	
OTHER (SPECIFY)	FLOOD PLA	AN DEVELOPMENT PERMIT	
PRE-DESIGN MEETING?	OTHER (SPI	ECIFY)	
DATE SUBMITTED: 08.02.2023			



46' ROW

3-1/2" TYPE 'C'

COURSE PER

6" AGGREGATE BASE

GEOTECHNICAL REPORT

PAVEMENT SECTION

BUFFER | SIDEWALK

4" CURB AND GUTTER

PER COA STD DWG 2415B

2%