

# CITY OF ALBUQUERQUE



May 15th, 2014

Yvette Tovar, P.E.  
New Mexico Water Collaborative  
1751 Bellamah NW #1101  
Albuquerque, NM 87104

**Re: Sawmill Pond Modification-Sawmill Village Wastewater Reuse**

Dear Ms. Tovar,

Based upon the information provided in your submittal received 5-9-14 and the easement, it is acceptable to build the wastewater reuse project in the Sawmill pond.

Hydrology understands that 2000 gallons/day will be pumped to the pond for irrigation.

If for some reason water is accumulating in the pond due to irrigation; at the point the volume reaches 0.5 acre-feet, a modification to the system may be required.

If you have any questions, you can contact me at 924-3986.

PO Box 1293

Albuquerque

New Mexico 87103

[www.cabq.gov](http://www.cabq.gov)

Sincerely,

Curtis Cherne, P.E.  
Principal Engineer, Hydrology  
Planning Dept.

C: e-mail