

# CITY OF ALBUQUERQUE



March 26, 2014

Gilbert Aldaz  
Applied Engineering and Surveying Inc.  
1605 Blair Drive NE  
Albuquerque, NM 87112

**Re: Hacienda Don Villegas  
Erosion Sediment Control (ESC) Plan  
Engineer's Stamp Date 3/06/2014 (H13/E053)**

Dear Mr. Aldaz,

Based upon your submittal received 3-06-14, the above referenced Erosion Sediment Control (ESC) plan is acceptable for Building Permit and Work Order.

This project requires a National Pollutant Discharge Elimination System (NPDES) permit for storm water discharge for disturbing one acre or more and a Topsoil Disturbance Permit for disturbing  $\frac{3}{4}$  of an acre or more.

If you have any questions, you can contact me at 924-3422.

Sincerely,

Shahab Biazar, P.E.  
Principal Engineer Planning Dept.  
Development Review Services

C: e-mail