

## Al-Najjar, Marwa G.

---

**From:** Al-Najjar, Marwa G.  
**Sent:** Friday, March 31, 2017 2:21 PM  
**To:** 'David Soule'  
**Cc:** Biazar, Shahab  
**Subject:** RE: Mesa Cold Storage Repave Project (file--h13d108)

David,

We have already reviewed it and we still need you to provide the following:

- Flow line elevations along the south side of the site.
- It appears there is a low spot elevation on the east side of the parking lot it will cause water harvesting.
- The sidewalk culvert invert shouldn't be the same as top of pond elevation.

Marwa Al-Najjar  
Associate Engineer  
Planning Department  
Office: (505) 924-3675  
[Mal-najjar@cabq.gov](mailto:Mal-najjar@cabq.gov)

---

**From:** David Soule [<mailto:david@riograndeengineering.com>]  
**Sent:** Friday, March 31, 2017 9:39 AM  
**To:** Al-Najjar, Marwa G.  
**Cc:** 'Melissa Baldonado'  
**Subject:** RE: Mesa Cold Storage Repave Project (file--h13d108)

Marwa, i am sorry to bother you, but i am following up on the review and hopefull approval of the resubmitted plans. I wanted to see when you anticipated being able to review. Thank you, i included the client because i wanted them to be aware as well. thank you  
David Soule  
Rio Grande Engineering

---

**From:** Al-Najjar, Marwa G. [<mailto:mal-najjar@cabq.gov>]  
**Sent:** Monday, March 13, 2017 9:56 AM  
**To:** 'DAVID@RIOGRANDEENGINEERING.COM'  
**Cc:** Biazar, Shahab  
**Subject:** Mesa Cold Storage Repave Project

Please find attached the comment letter for Mesa Cold Storage Repave Project.  
Thanks,

Marwa Al-Najjar  
Associate Engineer  
Planning Department  
Office: (505) 924-3675  
[Mal-najjar@cabq.gov](mailto:Mal-najjar@cabq.gov)