

CITY OF ALBUQUERQUE

Planning Department
Brennon Williams, Director



Mayor Timothy M. Keller

May 11, 2020

David Soule, P.E.
Rio Grande Engineering
P.O. Box 93924
Albuquerque, NM 87199

RE: 3010 12th St. NW
Request for Pad Certification – Accepted
Engineer's Stamp Date: 03/27/20
Engineer's Certification Date: 04/24/20
Hydrology File: H13D114

Dear Mr. Soule:

PO Box 1293

Based upon the information provided in your Certification received on 05/11/20 and site photos sent on 05/11/20, the above referenced Certification is acceptable for Building Pad Certification for 3010 12th St. NW.

Albuquerque

As a reminder, prior to approval in support of Permanent Release of Occupancy by Hydrology, Engineer Certification per the DPM checklist will be required.

NM 87103

If you have any questions, please contact me at 924-3995 or rbrissette@cabq.gov.

www.cabq.gov

Sincerely,

Renée C. Brissette, P.E. CFM
Senior Engineer, Hydrology
Planning Department



City of Albuquerque

Planning Department
Development & Building Services Division

DRAINAGE AND TRANSPORTATION INFORMATION SHEET (REV 6/2018)

Project Title: 3010 12th Street NW **Building Permit #:** _____ **Hydrology File #:** _____

DRB#: _____ **EPC#:** _____ **Work Order#:** _____

Legal Description: LOT 2 MacDonald Acres

City Address: 3010 12th street NW

Applicant: Belinda Barreras

Contact: _____

Address: _____

Phone#: _____ **Fax#:** _____ **E-mail:** _____

Other Contact: RIO GRANDE ENGINEERING

Contact: DAVID SOULE

Address: PO BOX 93924 ALB NM 87199

Phone#: 505.321.9099 **Fax#:** 505.872.0999 **E-mail:** david@riograndeengineering.com

TYPE OF DEVELOPMENT: _____ PLAT ☒ RESIDENCE _____ DRB SITE _____ ADMIN SITE

Check all that Apply:

DEPARTMENT:

☒ HYDROLOGY/ DRAINAGE
☐ TRAFFIC/ TRANSPORTATION

TYPE OF SUBMITTAL:

☐ ENGINEER/ARCHITECT CERTIFICATION
☒ PAD CERTIFICATION
☐ CONCEPTUAL G & D PLAN
☐ GRADING PLAN
☐ DRAINAGE REPORT
☐ DRAINAGE MASTER PLAN
☐ FLOODPLAIN DEVELOPMENT PERMIT APPLIC
☐ ELEVATION CERTIFICATE
☐ CLOMR/LOMR
☐ TRAFFIC CIRCULATION LAYOUT (TCL)
☐ TRAFFIC IMPACT STUDY (TIS)
☐ STREET LIGHT LAYOUT
☐ OTHER (SPECIFY) _____
☐ PRE-DESIGN MEETING?

IS THIS A RESUBMITTAL?: ☒ Yes ☐ No

TYPE OF APPROVAL/ACCEPTANCE SOUGHT:

☒ BUILDING PERMIT APPROVAL
☐ CERTIFICATE OF OCCUPANCY
☐ PRELIMINARY PLAT APPROVAL
☐ SITE PLAN FOR SUB'D APPROVAL
☐ SITE PLAN FOR BLDG. PERMIT APPROVAL
☐ FINAL PLAT APPROVAL
☐ SIA/ RELEASE OF FINANCIAL GUARANTEE
☐ FOUNDATION PERMIT APPROVAL
☐ GRADING PERMIT APPROVAL
☐ SO-19 APPROVAL
☐ PAVING PERMIT APPROVAL
☒ GRADING/ PAD CERTIFICATION
☐ WORK ORDER APPROVAL
☐ CLOMR/LOMR
☐ FLOODPLAIN DEVELOPMENT PERMIT
☐ OTHER (SPECIFY) _____

DATE SUBMITTED: _____ **By:** _____

COA STAFF:

ELECTRONIC SUBMITTAL RECEIVED: _____

FEE PAID: _____

Weighted E Method

Basin	Area (sf)	Area (acres)	100-Year, 6-hr.						10-day				
			Treatment A % (acres)	Treatment B % (acres)	Treatment C % (acres)	Treatment D % (acres)	Weighted (ac-ft)	Volume (ac-ft)	Flow cfs	Volume (ac-ft)			
EXISTING	17802.00	0.409	0%	0.36%	0.147	40%	0.163%	24%	0.398	1.242	0.042	1.31	0.055
PROPOSED	17802.00	0.409	0%	0.32%	0.131	34%	0.139	35%	0.143	1.376	0.047	1.41	0.066
COMPARISON	0.00	0.00	0%	0.000	-4%	-0.016	-4%	-0.025	11%	0.045	0.005	0.007	0.011

Equations:

Weighted E = Ea*As + Eb*Ab + Ec*Ac + Ed*Ad / (Total Area)

First flush requirement (Redevelopment)mpx.26/12- New developmentmpx.34/12

Volume = Weighted D * Total Area

REQUIRED

135

PROVIDED

2084 cubic feet

Flow = Qa * As + Qb * Ab + Qc * Ac + Qd * Ad

Where for 100-year, 6-hour storm

Qa= 1.56

Ea= 0.53

Eb= 0.78

Ec= 1.13

Ed= 2.12

Qb= 2.28

Qc= 3.14

Qd= 4.7

Developed Conditions

FLOOD CONTROL

INCREASE

TOTAL

10-DAY CF

460 CF

2877 CF

6-HOUR

199 CF

2041

PROVIDED

2084

2084

NARRATIVE

THIS PROJECT CONSISTS OF THE CONSTRUCTION OF A 1960 SQUARE FOOT ADDITION TO AND EXISTING HOUSE. THE DRIVEWAY AND FLATW/ REMAIN. THE REAR YARD WILL BE MODIFIED TO CAPTURE STORM WATER. SITE IS LOCATED IN THE VALLEY DRAINAGE AREA. THE SITE IS ALLOWED TO RETAIN ONSITE THE 100-YEAR, 6- HOUR VOLUME. THIS SITE SHAL RETAINS THE 100 YEAR, 6 HOUR VOLUME AS WELL AS THE INCREASE IN DISCHARGE COMPARED TO EXSTING DURING THE 10-DAY EVENT. THE YARD WILL OVERFLOW TO 12TH STREET IN AN EMERGENCY SITUATION


I, DAVID SOULE HAVE PERSONALLY INFECTED THE SITE. I HEREBY CERTIFY THE PAD HAS BEEN CONSTRUCTED SUCH THAT IT IS IN SUBSTANTIAL CONFORMANCE TO THE APPROVED GRADING PLAN DATED 3/27/20




5/11/20

EROSION CONTROL NOTES:

- CONTRACTOR IS RESPONSIBLE FOR OBTAINING A TOPSOIL DISTURBANCE PERMIT PRIOR TO BEGINNING WORK.
- CONTRACTOR IS RESPONSIBLE FOR MAINTAINING RUN-OFF ON SITE DURING CONSTRUCTION.
- CONTRACTOR IS RESPONSIBLE FOR CLEANING ALL SEDIMENT THAT GETS INTO EXISTING RIGHT-OF-WAY.
- REPAIR OF DAMAGED FACILITIES AND CLEANUP OF SEDIMENT ACCUMULATIONS ON ADJACENT PROPERTIES AND IN PUBLIC FACILITIES IS THE RESPONSIBILITY OF THE CONTRACTOR.
- ALL EXPOSED EARTH SURFACES MUST BE PROTECTED FROM WIND AND WATER EROSION PRIOR TO FINAL ACCEPTANCE OF ANY PROJECT.



VICINITY MAP: H-13-Z



FIRM MAP:

LEGAL DESCRIPTION:

3010 12TH STREET NW
CITY OF ALBUQUERQUE, BERNALILLO COUNTY, NEW MEXICO

NOTES:



- ALL SPOT ELEVATIONS REPRESENT FLOWLINE ELEVATION UNLESS OTHERWISE NOTED.
- ALL SLOPES SHALL BE 3:1 MAX. AND GRAVEL OR NATIVE SEEDING PRIOR TO CO.
- ANY PERIMETER WALLS MUST BE PERMITTED SEPARATELY. ALL RETAINING WALL DESIGN SHALL BE BY OTHERS.
- SURVEY INFORMATION PROVIDED BY COMMUNITY SCIENCES CORPORATION USING NAVD DATUM 1988.
- A PAD ELEVATION CERTIFICATION SHALL BE REQUIRED PRIOR TO RELEASE OF BUILDING PERMIT.

LEGEND

---	EXISTING CONTOUR
- - - - -	EXISTING INDEX CONTOUR
---	PROPOSED CONTOUR
---	PROPOSED INDEX CONTOUR
•	EXISTING SPOT ELEVATION
●	PROPOSED SPOT ELEVATION
---	BOUNDARY
---	PROPOSED EARTHEN SWALE
---	ADJACENT BOUNDARY
=====	EXISTING CURB AND GUTTER
=====	PROPOSED GRAVEL DRIVEWAY

CAUTION:

EXISTING UTILITIES ARE NOT SHOWN. IT SHALL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR TO CONDUCT ALL NECESSARY FIELD INVESTIGATIONS PRIOR TO ANY EXCAVATION TO DETERMINE THE ACTUAL LOCATION OF UTILITIES & OTHER IMPROVEMENTS.



ENGINEER'S SEAL	3010 12TH STREET	DRAWN BY DEM
DAVID SOULE NEW MEXICO REGISTERED PROFESSIONAL ENGINEER 14522	GRADING AND DRAINAGE PLAN	DATE 3-26-20
3/27/20	Rio Grande Engineering 1608 CENTRAL AVENUE SE SUITE 201 ALBUQUERQUE, NM 87106 (505) 972-0899	3010 12TH STREET.DWG
		SHEET # C1
DAVID SOULE P.E. #14522		JOB #