HYDROLOGY H14/D13 1 PLAN

H14/D13

1 Plan

City of Albuquerque
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

1114 - D13

May 17, 1982

Mr. Ted Witek
Acudemy Engineering
5353 Wyoming Blvd. NE, Suite 3
Albuquerque, N.M. 87109

RE: RAY ELECTRIC EXPANSION DRAINAGE REPORT

Dear Ted:

Please see that the following items are placed on the construction drawings:

a. Approximate elevation of the building located west of the project.

b. Additional spot elevations in the driveway areas.

c. Flowline and property line elevation at mid-point of new drivepad.

d. Location of roof drains.

e. Location of asphalt curb.

f. Revision date indicated by the Engineer's stamp.

Very truly yours,

Brian G. Burnett

Brian G. Burnett
Civil Engineer/Hydrology

BGB/tsl

City of Albuquerque
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

May 18, 1982

Mr. Ted Witek
Academy Engineering
5353 Wyoming Blvd. N.E.
Albuquerque, N.M. 87109

RE: RAY ELECTRIC ADDITION DRAINAGE REPORT

Dear Ted:

The referenced report is approved. Please see that the revised prints (dated 5/18/82) are placed in the City sets.

Very truly yours,

Brian G. Burnett
Civil Engineer/Hydrology

BGB/tsl

Academy Engineering, Inc.

May 13, 1982

Mr. Brian G. Burnett
Civil Engineer/Hydrology Dept.
City of Albuquerque
P.O. Box 1293
Albuquerque, NM 87103

Dear Brian:

This letter is in reference to our conversation on May 5, 1982 concerning drainage of the Ray Electric Office expansion. No ponding will be required due to the size of the project and the existing storm sewer facilities adjacent to the site.

Sincerely,

ACADEMY ENGINEERING, INC,

Ted X. Witek
Designer

RECEIVED
MAY 31 1982
ENGINEERING

H14-D13

In Concurrence

Brian G. Burnett
Civil Engineer/Hydrology
City of Albuquerque

5/18/82
Date

5353 WYOMING BLVD. NE SUITE 3 ALBUQUERQUE, N.M. 87109 (505) 821-8008

City of Albuquerque
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DRAINAGE REPORT INFORMATION SHEET

PROJECT TITLE DRAINAGE PLAN RAY ELECTRIC

ZONE ATLAS PAGE NO. H-14 CITY ADDRESS

LEGAL ADDRESS 2505 6th NW

ENGINEERING FIRM ACADEMY ENGINEERING CONTACT JIM BLACKWELL

ADDRESS 5353 WYO BLVD NE SUITE 3 PHONE 821-8008

OWNER RAY GUTIERREZ CONTACT

ADDRESS 2505 6th NW PHONE 842-9946

ARCHITECT/SURVEYOR CONTACT

ADDRESS PHONE

DATE SUBMITTED MAY 13, 1982

BY TED WITEK

RECEIVED

MAY 13 1982

ENGINEERING

MUNICIPAL DEVELOPMENT DEPARTMENT
Richard S. Heller, P.E., City Engineer ENGINEERING DIVISION Telephone (505) 766-7187

Academy Engineering, Inc.

May 13, 1982

Mr. Brian G. Burnett
Civil Engineer/Hydrology Dept.
City of Albuquerque
P.O. Box 1293
Albuquerque, NM 87103

Dear Brian:

This letter is in reference to our conversation on May 5, 1982 concerning drainage of the Ray Electric Office expansion. No ponding will be required due to the size of the project and the existing storm sewer facilities adjacent to the site.

Sincerely,

ACADEMY ENGINEERING, INC,

Ted X. Witek
Designer

In Concurrence

Brian Burnett
Civil Engineer/Hydrology
City of Albuquerque

Date

RECEIVED

MAY 13 1982

ENGINEERING

(505) 821-6008
ALBUQUERQUE, N.M. 87109
5151 WYOMING BLVD. NE. SUITE 3

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DRAINAGE REPORT INFORMATION SHEET

PROJECT TITLE DRAINAGE PLAN RAY ELECTRIC

ZONE ATLAS PAGE NO. H-14 CITY ADDRESS

LEGAL ADDRESS 2505 6th NW

ENGINEERING FIRM ACADEMY ENGINEERING CONTACT JIM BLACKWELL

ADDRESS 5353 WYO BLVD NE SUITE 3 PHONE 821-8008

OWNER RAY GUTIERREZ CONTACT

ADDRESS 2505 6th NW PHONE 842-9946

ARCHITECT/SURVEYOR CONTACT

ADDRESS PHONE

DATE SUBMITTED MAY 13, 1982

BY TED WITEK

RECEIVED

MAY 13 1982

ENGINEERING

MUNICIPAL DEVELOPMENT DEPARTMENT

Richard S. Heller, P.E., City Engineer ENGINEERING DIVISION

Academy Engineering, Inc.

May 13, 1982

Mr. Brian G. Burnett
Civil Engineer/Hydrology Dept.
City of Albuquerque
P.O. Box 1293
Albuquerque, NM 87103

Dear Brian:

This letter is in reference to our conversation on May 5, 1982 concerning drainage of the Ray Electric Office expansion. No ponding will be required due to the size of the project and the existing storm sewer facilities adjacent to the site.

Sincerely,

ACADEMY ENGINEERING, INC,

Ted X. Witek
Designer

In Concurrence

Brian Burnett
Civil Engineer/Hydrology
City of Albuquerque

Date

RECEIVED
MAY 13 1982
ENGINEERING

(505) 821-8008
ALBUQUERQUE, N.M. 87109
5151 WYOMING BLVD. NE SUITE 1