HYDROLOGY

H14/D46

GEORGE CHAVEZ STORAGE

BLDG. SIXTH N.W.

H14-D46

1 PLAN

CITY OF ALBUQUERQUE
MUNICIPAL DEVELOPMENT DEPARTMENT
ENGINEERING DIVISION/DESIGN HYDROLOGY SECTION

CONFERENCE RECAP

DRAINAGE FILE/ZONE ATLAS PAGE NO.: ~~H14~~ DATE: ~~3-19-86~~
PLANNING DIVISION NOS: EPC: _____ DRB: _____
SUBJECT: ~~Storm Drg~~
STREET ADDRESS (IF KNOWN): ~~Lot 8~~ ~~Monk Alden~~
SUBDIVISION NAME: _____

APPROVAL REQUESTED:

____ PRELIMINARY PLAT	____ FINAL PLAT
____ SITE DEVELOPMENT PLAN	____ BUILDING PERMIT
____ OTHER	✓ ROUGH GRADING

	WHO	REPRESENTING
ATTENDANCE:	~~Duane Lose~~	
	~~Carlos Montoya~~	

FINDINGS:

① ~~Drainage Plan per DPM~~

② ~~Free discharge allowed, engineer must address~~
~~(A) infill site~~
~~(B) minimum impact~~
~~(C) storm drain in street~~
~~(D) Not flood zone.~~
~~(E) 1200 cfs Alley.~~

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: Carlos A Montoya SIGNED: [illegible]
TITLE: _____ TITLE: [illegible]
DATE: 3-19-86 DATE: [illegible]

NOTE PLEASE PROVIDE A COPY OF THIS RECAP WITH THE DRAINAGE SUBMITTAL

THIS MICROIMAGE IS THE BEST POSSIBLE REPRODUCTION DUE TO THE POOR QUALITY OF THE ORIGINAL DOCUMENT

DRAINAGE INFORMATION SHEET

CITY OF ALBUQUERQUE, N.M.

PROJECT TITLE: Storage Building ZONE ATLAS/DRNG. FILE #: H14/D46

LEGAL DESCRIPTION: Lot 8, Monk Addition

CITY ADDRESS: 2637 6th St., NW

ENGINEERING FIRM: Logan/Gross CONTACT: Duane Logan

ADDRESS: 501 Kinley, NE PHONE: 243-6353

OWNER: George Chavez CONTACT: Same

ADDRESS: 13315 Tierra Montanosa Dr., NE PHONE: 292-4313

ARCHITECT: CMA Architects CONTACT: Roger Cinelli

ADDRESS: 1020 Tijeras NR PHONE: 842-5892

SURVEYOR: Logan/Gross CONTACT: Duane Logan

ADDRESS: 501 Kinley, NE PHONE: 243-6353

CONTRACTOR: Not Selected CONTACT:

ADDRESS: PHONE:

RECEIVED APR 02 1986 HYDROLOGY SECTION

PRE-DESIGN MEETING:

XXX YES

___ NO

XXX COPY OF CONFERENCE RECAP SHEET PROVIDED

DRB NO. ___

EPC NO. ___

PROJ. NO. ___

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT

XXX DRAINAGE PLAN

___ CONCEPTUAL GRADING & DRAINAGE PLAN

___ GRADING PLAN

___ EROSION CONTROL PLAN

___ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL

___ PRELIMINARY PLAT APPROVAL

___ SITE DEVELOPMENT PLAN APPROVAL

___ FINAL PLAT APPROVAL

XXX BUILDING PERMIT APPROVAL

X FOUNDATION PERMIT APPROVAL

___ CERTIFICATE OF OCCUPANCY APPROVAL

___ ROUGH GRADING PERMIT APPROVAL

___ GRADING/PAVING PERMIT APPROVAL

___ OTHER ___ (SPECIFY)

DATE SUBMITTED: April 2, 1986

BY: Duane Logan

FILE COPY

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION
123 Central NW, Albuquerque, NM 87102
(505) 766-7644

April 3, 1986

Duane Logan
Logan/Gross Engineering
501 Kinley, NE
Albuquerque, New Mexico 87102

RE: DRAINAGE PLAN FOR STORAGE BUILDING AT 2637 SIXTH STREET, NW
(H-14/D46) RECEIVED APRIL 2, 1986

Dear Duane:

Based on the information provided on your April 2, 1986 submittal, the above referenced drainage plan is approved for Building Permit and Foundation Permit approval.

Please attach a copy of this approved drainage plan to the construction set prior to sign-off by Hydrology.

If you have any questions regarding this project, call me at 766-7644.

Cordially,

Bernie J. Montoya

Bernie J. Montoya, C.E.
Engineering Assistant

BJM/bsj

cc: George Chavez