



**City of Albuquerque Stormwater Construction Site Inspection Report**

General Information					
ESC File No.	H14E110	Project Name:	U-Haul Albuquerque Westside		
NPDES Id. No.	NMR1003MS	Location:	2217 4th Street		
8/11/2021	Owner	Contractor			
Operator	Amerco Real Estate Company				
Contact name & title	Tom Neill				
e-mail	<a href="mailto:tom_neill@uhaul.com">tom_neill@uhaul.com</a>				
Contact Phone #	505-259-0339				
COA Inspector	Thomas Evans		Start/End Time:	12:45 PM-12:50 PM	
Construction Phase:	Pre-construction, BMP's				
Type of Inspection:	<input checked="" type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Past Storm Event >0.25"	<input type="checkbox"/> 311/Complaint	<input type="checkbox"/> Follow Up
Weather at time of inspection?	clear		Temperature: ~	84	
Estimated date of last storm 0.25" or greater	5/31/2021				

Item Number	Deficiency/ Corrective Action				
1	No posting of NOI permit coverage. Post signage of NOI permit coverage in a location clearly visible to the public.				
2	Construction Entrance missing.				
3	SWPPP not available onsite				
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	Requested	Latest report Date:	None on file	

Notes:	Silt fence and mulch socks have been installed. Grading activity on site.

City of Albuquerque Stormwater Inspector Signature and date:  
 Contact information: [James D. Hughes](mailto:James.D.Hughes@cabq.gov) (505-803-6215)  
[jhughes@cabq.gov](mailto:jhughes@cabq.gov)

**08/12/2021**  
*James D. Hughes*