

City of Albuquerque Stormwater Construction Site Inspection Report

General information								
SC File No.	H14E	112 Project Name:		Broadway/McKnight Apartments				
IPDES Id. No.	NMR10	003ZY Location:		4701 4th St. NW				
8/25/2022		Owner			Contractor			
Operator		Albuquerque Housing Authority			Pavilion			
Contact name & title		Daniel Foster			Todd Lay			
e-mail		dfoster@abqha.org			tlay@pavillionconstruction.com 530-0921			
Contact Phone #		505-764-3925						
COA Inspector		Doug Hughes			Start/End Time: 10-10:30AM			
Construction Phase:		vertical Regular Storm Event Past Storm Event > 0.25"						
Type of Inspection:		Regular	Storm Event			311/Complaint	Follow Up	
Weather at time of i		nspection? Clear			Temperature: ~ 75			
Estimated date of last storm 0.25" or greater 8/1/2022								
Item	Deficiency/ Corrective Action							
Number	Deficiency/ Corrective Action							
1	The trackout pad is full of sediment and needs reset, and there is a dirt ramp in McKnight street that isn't							
-	allowed. Sediment in McKnight is begining to obscure the pavement (See Photos). Implement additional							
	track-out controls as necessary to ensure that sediment removal occurs prior to vehicle exit; and where							
	sediment has been tracked-out from your site onto paved roads, sidewalks, or other paved areas outside							
	of your site, remove the deposited sediment by the end of the same business day in which the track-out							
	occurs or by the end of the next business day if track-out occurs on a non-business day. Remove the							
	track-out by sv	ck-out by sweeping, shoveling, or vacuuming these surfaces, or by using other similarly effective						
	means of sediment removal. You are prohibited from hosing or sweeping tracked-out sediment into any							
	constructed or natural site drainage feature, storm drain inlet, or receiving water.							
	constructed of flatural site drainage reactive, storm drain inlet, of receiving water.							
2								
3								
4								
2.1	Discharge off site?	(Y/N)	no					
4	Self Inspect	tion Reports	required	Latest rep	port Date:	8/1/20)22	
Notes:	rs: The SWPPP is in the contractor's trailer onsiteand up-to-date.							
Building Construction was vertical but no occupancy yet.								

City of Albuquerque Stormwater Inspector Signature and date:

Contact information: Doug Hughes (505-924-3420)

jhughes@cabq.gov