

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

April 4, 1996

R.G. Lee Lee Engineering 2316 Calle de Rafael NE Albuquerque, NM 87122

RE: ENGINEER CERTIFICATION FOR CANDELARIA COMMERCE CENTER

(H15-D54) CERTIFICATION STATEMENT DATED 3/27/96.

Dear Mr. Lee:

Based on the information provided on your March 28, 1996 submittal, Engineer Certification for the above referenced site is acceptable.

If I can be of further assistance, please feel free to contact me at 768-2667.

Sincerely,

Bernie J. Montoya, CE Engineering Associate

BJM/dl

c: Andrew Garcia

File.



P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

November 29, 1995

R.G. Lee Lee Engineering 2316 Calle de Rafael NE Albuquerque, NM 87122

RE: REVISED DRAINAGE PLAN FOR CANDELARIA COMMERCE CENTER

(H15-D54) REVISION DATED 11/21/95.

Dear Mr. Lee:

Based on the information provided on your November 28, 1995 resubmittal, the above referenced site is approved for Building Permit.

If the building permit has already been issued it is your responsibility to assure that the contractor is given a copy of the revised plan.

Also, a separate permit is required for construction within City Right-of-Way. A copy of this approval letter must be on hand when applying for the excavation permit.

Prior to Certificate of Occupancy release, Engineer Certification per the D.P.M. checklist will be required.

If I can be of further assistance, please feel free to contact me at 768-2667.

Sincerely,


Bernie J. Montoya, CE Engineering Associate


BJM/dl

c: Andrew Garcia
Arlene Portillo
Ken Hovey
File

CANDELARIA COMMERCE

PROJECT TITLE:	CENTER ZON	IE ATLAS/DRWNG. FILE #: H15-D54		
LEGAL DESCRIPTION:	LOT 1, TRACT E SUND'T INDUSTRIAL PARK, ALBUQUERUQUE, NEW MEXICO			
CITY ADDRESS:	CANDELARIA BLVD. NE			
ENGINEER FIRM:	LEE ENGINEERING	CONTACT: R.G. Lee, Jr.		
ADDRESS:	2316 CALLE DE REFAEI	N.E. PHONE: (505) 822-8999		
	ALBUQUERQUE N.M. 87	122		
ARCHITECT:	KEN HOVEY	CONTACT:		
ADDRESS:		PHONE: (505) 822-8999		
OWNER:		CONTACT:		
ADDRESS:		PHONE:		
SURVEYOR:		CONTACT:		
ADDRESS:		PHONE:		
CONTRACTOR:		CONTACT:		
ADDRESS:		PHONE:		
PRE-DESIGN MEETING	કે:			
YES		DRB NO.		
X_NO		EPC NO.		
COPY OF CONFE	RENCE RECAP	PROJ.NO		
SHEET PROVIDE				
TYPE OF SUBMITTAL:		CHECK TYPE OF APPROVAL SOUGHT:		
DRAINAGE REPC		SKETCH PLAT APPROVAL		
DRAINAGE PLAN		PRELIMINARY PLAT APPROVAL		
	RADING & DRAINAGE PLAN	SITE DEVELOPMENT PLAN APPROVAL		
GRADING PLAN		FINAL PLAT APPROVAL		
EROSION CONTROL PLAN		BUILDING PERMIT APPROVAL		
X ENGINEER' CERTIFICATION		ROUGH GRADING PERMIT APPROVAL		
		GRADING/PAVING PERMIT APPROVAL		
		X OTHER "CERTIFICATE OF OCCUPANCY		
DATE	SUBMITTED: March 28, 1996			
	BY: Herman Hood			





P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

November 17, 1995

R.G. Lee Lee Engineering 2316 Calle de Rafael NE Albuquerque, NM 87122

RE: REVISED DRAINAGE PLAN FOR CANDELARIA COMMERCE CENTER

(H15-D54) REVISION DATED 11/15/95.

Dear Mr. Lee:

Based on the information provided on your November 16, 1995 resubmittal, listed are some concerns that will need to be addressed prior to final approval.

- 1. Further review of the initial approved plan indicates that changes have been implemented other than the dock area.
- 2. Inlet & pipe calculations must be shown to verify capacity. Use orifice and Weir formulas.
- 3. Pipes with longer than 100' will require cleanouts.

If I can be of further assistance, please feel free to contact me at 768-2667.

Sincerely,

Bernie J. Montoya, CE
Engineering Associate

BM/dl

c: Andrew Garcia

File

	ZONE ATLAS/DRNG. FILE #: H.15/454
DRB #: EPC #:	
LEGAL DESCRIPTION: LOT 1 TRACT & SU	
CITY ADDRESS: 1420 CANOELARIA WE	
ENGINEERING FIRM: R.C. LEE	CONTACT:
ADDRESS: 2316 CALLE DE PAFAEL	<u>W£</u> PHONE: <u>\$22-8999</u>
OWNER: WAREHOSING COMPANT OF UM	CONTACT:
ADDRESS: Pio.Box 6127 Aug. U.m.	PHONE: 269.4229
ARCHITECT: KEN HOVEY	CONTACT:
ADDRESS: 3808 Symms SE ALB N	M. PHONE: 255-9400
SURVEYOR:	CONTACT:
ADDRESS:	PHONE:
CONTRACTOR:	CONTACT:
ADDRESS:	PHONE:
TYPE OF SUBMITTAL: DRAINAGE REPORT DRAINAGE PLAN CONCEPTUAL GRADING & DRAINAGE PLAN GRADING PLAN EROSION CONTROL PLAN ENGINEER'S CERTIFICATION OTHER PE-SUBYMITTAL TO RICK UP COMMENTED PRE-DESIGN MEETING: YES NO COPY PROVIDED	CHECK TYPE OF APPROVAL SOUGHT: SKETCH PLAT APPROVAL PRELIMINARY PLAT APPROVAL S. DEV. PLAN FOR SUB'D. APPROVAL S. DEV. PLAN FOR BLDG. PERMIT APPROVAL SECTOR PLAN APPROVAL FINAL PLAT APPROVAL FOUNDATION PERMIT APPROVAL CERTIFICATE OF OCCUPANCY APPROVAL GRADING PERMIT APPROVAL PAVING PERMIT APPROVAL S.A.D. DRAINAGE REPORT DRAINAGE REQUIREMENTS (SUBDIVISION CERTIFICATION
	OTHER(SPECIFY)
	1

DATE SUBMITTED: 11.16.95

BY: Karhyn Honey

1.1610

4 AZ 5.

REASTAND PRESTLY
SVEMITTAL PRESTLY
TO BERNIE AFTER
TO BERNIE A

THANKS!

ţ .

•

PROJECT TITLE: CANDELARIA COMMERCE AZONE ATLAS/DRNG. FILE #: DRB #: EPC #: DIEROIS MM - 1420 CHARU ENGINEERING FIRM: CONTACT: 856-1512 ADDRESS: PHONE: KEMHOVEY CONTACT: ARCHITECT: ADDRESS: 3808 Symms ANG SE PHONE: 255-94-00 SURVEYOR: CONTACT: ADDRESS: PHONE: CONTRACTOR: CONTACT: ADDRESS: PHONE: TYPE OF SUBMITTAL: CHECK TYPE OF APPROVAL SOUGHT: DRAINAGE REPORT SKETCH PLAT APPROVAL DRAINAGE PLAN PRELIMINARY PLAT APPROVAL CONCEPTUAL GRADING & DRAINAGE PLAN ____ S. DEV. PLAN FOR SUB'D. APPROVAL ____ GRADING PLAN S. DEV. PLAN FOR BLDG. PERMIT APPROVAL EROSION CONTROL PLAN SECTOR PLAN APPROVAL ENGINEER'S CERTIFICATION ____FINAL PLAT APPROVAL OTHER ____ FOUNDATION PERMIT APPROVAL BUILDING PERMIT APPROVAL PRE-DESIGN MEETING: CERTIFICATE OF OCCUPANCY APPROVAL GRADING PERMIT APPROVAL YES NO ____ PAVING PERMIT APPROVAL 2 8 1995 COPY PROVIDED ____ S.A.D. DRAINAGE REPORT DRAINAGE REQUIREMENTS SUBDIVISION CERTIFICATION OTHER (SPECIFY) DATE SUBMITTED:

BY:



P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

August 29, 1994

R.G. Lee Lee Engineering 2316 Calle de Rafael NE Albuquerque, NM 87122

> REVISED DRAINAGE PLAN FOR CANDELARIA COMMERCE CENTER (H15-D54) RE: REVISION DATED 8/18/94.

Dear Mr. Lee:

Based on the information provided on your August 19, 1994 resubmittal, the above referenced site is approved for Building Permit.

Please attach a copy of this approved plan to the construction sets prior to sign-off by Hydrology.

Also, a separate permit is required for construction within City Right-of-Way. A copy of this approval letter must be on hand when applying for the excavation permit.

Prior to Certificate of Occupancy release, Engineer Certification per the D.P.M. Checklist will be required.

If I can be of further assistance, please feel free to contact me at 768-2667.

Sincerely,

Bernie J. Wontoya, CE Engineering Associate

BJM/d1/WPHYD/8623

Andrew Garcia C: Arlene Portillo File

CANDELARIA	11-15/254
PROJECT TITLE: COMMETCE CENTER	ZONE ATLAS/DRNG. FILE N. H-15/25/
LEGAL DESCRIPTION. LOT IL AFFICA E.	SUMUIS TIVUSITION.
CITY ADDRESS: 1450 CANDRLAR	
	ING CONTACT: R.G. LEE.
ADDRESS: 2316 CALLE DE RAF	AEL PHONE:
DWNER. WAREHOUSING CO. OF N	M CONTACT: RAY COHEN
ADDRESS: P.O. BOX 6127, ALBQ	KW DUDNE. 856-7522
ADDRESS: [.V. DCW Colonial Col	LEN-HOVEY
ARCHITECT: KEN HOVEY DESIGN GR	CONTACT: TOTAL
ADDRESS:335 JEFFERSON SE.	B PHONE: 299
SURVEYOR:	CUNTACT:
ADDRESS:	PHONE:
	CONTACT:
CONTRACTOR:	•
ADDRESS:	PHONE:
34	
PRE-DESIGN MEETING:	
YES	DRB NO.
NO	EFC NO PROJ. NO
COPY OF CONFERENCE RECAP SHEET PROVIDED	FROJ. NO.
TYPE OF SUBMITTAL:	CHECK TYPE OF APPROVAL BOUGHT:
DRAINAGE REPORT	SKETCH PLAT APPROVAL :
DRAINAGE PLAN	PRELIMINARY PLAT APPROVAL
CONCEPTUAL GRADING & DRAINAGE PLAN	SITE DEVELOPMENT PLAN APPROVAL
GRADING PLAN	FINAL PLAT APPROVAL
ERDSION CONTROL FLAN	BUILDING FERMIT APPROVAL
ENGINEER'S CERTIFICATION	FOUNDATION PERMIT APPROVAL CERTIFICATE OF OCCUPANCY APPROVAL
	ROUGH GRADING PERMIT APPROVAL
	GRADING/PAVING PERMIT APPROVAL
	OTHER (SPECIFY)
DATE SUBMITTED: 0/4/94	
BY: KEN HOVET	JUN 1 4 1994
• • • • • • • • • • • • • • • • • • •	



P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

June 28, 1994

R.G. Lee Lee Engineering 2316 Calle de Rafael NE Albuquerque, NM 87122

RE: DRAINAGE PLAN FOR CANDELARIA COMMERCE CENTER (H15-D54) ENGINEER'S STAMP DATED 6/10/94.

Dear Mr. Lee:

Based on the information provided on your June 14, 1994 submittal, listed are some concerns that will need to be addressed prior to final approval:

- 1. Discharge rate must be held to 1.0 cfs, due to downstream constraints.
- 2. Use the new volume 2 Design Criteria to develop your hydrograph.

If I can be of further assistance, please feel free to contact me at 768-2667.

Sincerely,

Bernie J. Montoya, CE Engineering Associate

BJM/d1/WPHYD/8623

c: File-

PROJECT TITLE: CANDELARIA COMMERCE CENT	ER ZONE ATLAS/DRNG. FILE W: 4/5 454
LEGAL DESCRIPTION: LOT 1, TRACT E CITY ADDRESS: 1450 CANDELARY	SUNDT'S INDUSTRIAL AREA
CITY ODDRESS. 1450 CANDELARY	A BLVD. NE
ENGINEERING FIRM: LEE ENGINEERING	G CONTACT: RG LEE
ADDRESS: 2316 CALLE DE RAFAEL	PHONE: 822-8999
DWNER: WAREHOUSING CO. OF NY	
ADDRESS: P.O. BOX 6127, ALBQ1	ALL PHONES OF LANGY
ARCHITECT: KEN HOVEY PESIGN GR	CONTACT: CELOAOO
ADDRESS: 335 JEFFERSON SE SI	DITES PHONE: 400 TO
SURVEYOR:	CUNTACT:
ADDRESS:	PHONE
CONTRACTOR:	CONTACT:
ADDRESS:	PHUNE:
PRE-DESIGN MEETING:	
YES .	DRB ND.
NO	EFC NO.
COPY OF CONFERENCE RECAP SHEET PROVIDED	PROJ. NO.
Stiedi Provide	
TYPE OF SUBMITTAL:	CHECK TYPE OF APPROVAL BOUGHT:
DRAINAGE REPORT	SKETCH PLAT APPROVAL :
DRAINAGE PLAN	PRELIMINARY PLAT APPROVAL
CONCEPTUAL GRADING & DRAINAGE PLAN	SITE DEVELOPMENT PLAN APPROVAL
X. GRADING PLAN	FINAL PLAT APPROVAL
ERDSION CONTROL PLAN	BUILDING FERMIT APPROVAL
ENGINEER'S CERTIFICATION FOUNDATION PERMIT APPROVAL	
	CERTIFICATE OF OCCUPANCY APPROVAL
	ROUGH GRADING PERMIT APPROVAL
	GRADING/FAVING PERMIT APPROVAL
	OTHER (SPECIFY)
DATE SUBMITTED: 18 AUGUST 19	94
DATE SUBMITTED:	RESUBMITTAL
	· · · · · · · · · · · · · · · · · · ·

CITY OF ALBUQUERQUE PUBLIC WORKS DEPARTMENT UTILITY DEVELOPMENT DIVISION/HYDROLOGY SECTION

PRE-DESIGN CONFERENCE

DRAINAGE FILE/ZONE ATLAS PAGE NO.: $H-15$ DATE: $1-26-94$	
EPC NO.: DRB NO.: ZONE: $M-2$	
SUBJECT: Candelaria Commerce Center	
STREET ADDRESS: Candelaria	
LEGAL DESCRIPTION: Lot 1 Tract E Suncits Industri	· /
BHORE DECORITION.	<i>ن</i>
APPROVAL REQUESTED: PRELIMINARY PLAT FINAL PLAT	
SITE DEVELOPMENT PLAN BUILDING PERMIT	
GRADING/PAVING PERMIT OTHER	
GRADING/INVING IBRUILI OTHER	
WHO REPRESENTING	
ATTENDANCE: Ken Hovey Ken Hovey	
John Curtin C.O.A./PWD/Hyd	
FINDINGS:	
Panel 23 Indicates site 15 mot in a	
floodofain but drains to a +loodylain	
next to the railroad Tracks.	
To Keen from aggravating downstream	
problems developed runott is limited	/
to existing rate. Theretone detent	101
will be required. Identity any a off-site Hows.	
Use New DPM ANdrology, Evalua	7/2
100 110 an 6 hour storm and 10 voan-	
Chour storm Discharge is limited to	7
the existing 100 vear-6 hour rate.	
*	
*	
The undersigned agrees that the above findings are summarized accurately and are only	
subject to change if further investigation reveals that they are not reasonable or that	
they are based on inaccurate information.	
SIGNED: SIGNED: SIGNED: SIGNED:	
TITLE: KRINTUSOT TITLE: / _ /////////////////////////////////	
DATE: JAM, 26, 1995 DATE: DATE:	
NOTE PLEASE PROVIDE A COPY OF THIS PRE-DESIGN FORM WITH THE DRAINAGE SUBMITTAL.	

