

CITY OF ALBUQUERQUE



February 8, 2017

David Tull, P.E.
Superior Stormwater Services, LLC
8505 Paseo Alameda NE
Albuquerque, NM 87113

**Re: Galles Chevrolet
Erosion and Sediment Control Plan
Engineer's Stamp Date 1-3-17 (H15E065)**

Dear Mr. Tull,

Based upon the information provided in your submittal received 2-3-17 the above referenced plan is approved to be included in the SWPPP and to apply for an ESC permit for grading and Building Permit.

Please consider straw wattles or similar erosion protection on the slopes in the southwest area and grading the pond in the southwest corner early in the development process.

PO Box 1293

Include a copy of the approved plan in the Building Permit set.

Albuquerque

If you have any questions, you can contact me at 924-3420.

New Mexico 87103

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

www.cabq.gov

C: email