HYDROLOGY H16/D8 FOUR PLANS

H16/D8

4 Plans

ENCHANTMENT ENGINEERING, INC.
CIVIL CONSULTING ENGINEERS
J.W. BETTIS, REG. P.E. & L.S.
1517 EUBANK N.E.
PHONE 294-8859
MAIL TO BOX 11571
ALBUQUERQUE, NEW MEXICO 87192

October 30, 1980

Mr. Richard Heller,
City Engineer,
City of Albuquerque, New Mexico.

Re: Los Cedros Apartments

Dear sir-

These Apartments have been constructed by Crown Mining Co., and are now complete. However, the final drainage pattern was not completed in accordance with City approved drawings.

In order to conform to the approved drawings it would be necessary to redo much of the finish grading.

We have re-calculated the run-off.

I have discussed this matter with Bruno, and determined that the recently installed drainage facility and catch basin is adequate to handle the run-off. The supplemental drawing is self explanatory and we are therefore asking that the original approved drawings be waived and your acceptance of this revised plan.

Respectfully,

J. W. Bettis, Reg. P.E. & L.S. N.M. # 3441

Stephen Durkovich

RECEIVED
OCT 30 1980
CITY ENGINEER

RSH	RSA	ADM	
HRD	HRD	SUR	
CDS		COUN	
DES		SEC	
INSP		FILE	
HYDRO		RETURN	

Respond by 11/10

City of Albuquerque
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

August 8, 1979

Enchantment Engineering
1517 Eubank N.E.
Albuquerque, New Mexico 87111

Re: 72 Unit Apartment Project, Unit 3, Indian Plaza Addition

Attention: John Bettis

Dear John:

Your drainage report of July, 1979 has been reviewed by staff and is approved in concept. Positive discharge for all of the ponding areas must be provided in a satisfactory manner unless percolation tests and maintenance procedures are provided for positive infiltration.

Should you have any questions, please feel free to contact the Hydrology Section - City Engineer's Office.

Very truly yours,

Richard S. Heller
City Engineer

RSH/fs

cc - Fred Aguirre, Assistant Hydrology Engineer
Rich Leonard, AMAFCA
Drainage File

0998