

CITY OF ALBUQUERQUE



December 05, 2011

Ronald Ray Bohannon, P.E.
Tierra West, LLC.
5571 Midway Park Place N.E.
Albuquerque, NM 87109

Re: Chipolte Restaurant, 6810 Menaul Blvd. NE,
Request for Permanent C.O. - Approved
Engineer's Stamp dated: 07-12-11 (H-19/D058)
Certification dated: 12-05-11

Dear Mr. Bohannon,


Based upon the information provided in the Certification received 12-05-11, the above referenced Certification is approved for a release of a Permanent Certificate of Occupancy by Hydrology.

The northwest corner of the site, along Menaul and Louisiana, a swale was constructed to convey the roof drains from Chipotle to Louisiana. Unfortunately, at the time of approval this was not anticipated. Per the DPM nuisance flow is not allowed to discharge over the sidewalk. Any future issues with this design will need to be mitigated through your office.

Hydrology is asking for an electronic copy, in .pdf format, of this certification for our records. This certification can be e-mailed to me at: tsims@cabq.gov.

If you have any questions, you can contact me at 924-3982.

Sincerely,


Timothy E. Sims,
Plan Checker—Hydrology Section
Development and Building Services

C: CO Clerk—Katrina Sigala
File