

City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	H19E090	Project Name:	US Eagle FCU Menaul Branch			
NPDES Id. No.	NMR1003M3/NMR1003MO	Location:	7201 Menaul Blvd. NE			
6/3/2021	Owner		Contractor			
Operator	US Eagle FCU		Enterprise Builders			
Contact name & title	Michael Moore		Ralph Baldwin			
e-mail	mmoore@useagle.org		rpb@ebnm.com			
Contact Phone #	505-342-8888		505-857-0050			
COA Inspector	Thomas Evans		Start/End Time:	3:15 PM-3:25 PM		
Construction Phase:	infrastructure					
Type of Inspection:	Regular	Storm Event	Past Storm Event >0.25"	311/Complaint	Follow Up	
Weather at time of inspection?	clear		Temperature: ~	88		
Estimated date of last storm 0.25" or greater	5/31/2021					
Item Number	Deficiency/ Corrective Action					
1	Sediment on sidewalk. Reposition mulch socks to prevent sediment from exiting the site. Sweep track-out and sediment daily.					
2	Wind screen missing in some sections. Install wind screen across all sections of the perimeter fence as shown in the ESC Plan.					
2.1	Discharge off site? (Y/N)		no			
4	Self Inspection Reports		Received	Latest report Date:	6/9/2021	

Notes:	Nobody from Enterprise Builders on site. Only TLC Plumbing was working on site.

City of Albuquerque Stormwater Inspector Signature and date:

Contact information: Thomas Evans (505-803-6215)
tevans@cabq.gov

Thomas Evans 06/15/2021