

**CITY OF ALBUQUERQUE  
PLANNING DEPARTMENT  
HYDROLOGY DEVELOPMENT SECTION**

**WAIVER APPLICATION FROM STORMWATER  
QUALITY VOLUME MANAGEMENT ON-SITE**

---

**GENERAL INFORMATION**

---

APPLICANT: SMM PE, LLC DATE: 8/19/25

DEVELOPMENT: 2500 Louisiana Blvd NE

LOCATION: NE Corner of Louisiana and Prospect NE

HYDROTRANS # H19D095

**STORMWATER QUALITY POND VOLUME**

---

Per the DPM Article 6-12 - Stormwater Quality and Low-Impact Development, the calculated sizing for required Stormwater Quality Pond volume is equal to the impervious area draining to the BMP multiplied by 0.42 inches for new development sites and by 0.26 inches for redevelopment sites.

The required volume is 1659 cubic feet

The provided volume is 238 cubic feet

The deficient volume is 1421 cubic feet

---

**WAIVER JUSTIFICATION**

---

Per the DPM Article 6-12(C), private off-site mitigation and payment-in-lieu may only be considered if management on-site is waived in accordance with the following criteria and procedures.

1. Management on-site shall be waived by the City Engineer if the following conditions are met:

- a. Stormwater quality can be effectively controlled through private off-site mitigation or through an arrangement (approved by the City) to use a cooperators existing regional stormwater management infrastructure or facilities that are available to control stormwater quality.
- b. Any of the following conditions apply:
  - i. The lot is too small to accommodate management on site while also accommodating the full plan of development.
  - ii. The soil is not stable as demonstrated by a geotechnical report certified by a professional engineer licensed in the State of New Mexico.
  - iii. The site use is inconsistent with the capture and reuse of stormwater.
  - iv. Other physical conditions exist where compliance with on-site stormwater quality control leaves insufficient area.
  - v. Public or private off-site facilities provide an opportunity to effectively accomplish the mitigation requirements of the Drainage Ordinance (Part 14-5-2 ROA 1994) as demonstrated on as-built construction drawings and an approved drainage report.
  - vi. The developer constructs a project to replenish regional groundwater supplies at an off-site location.
  - vii. A waiver to State water law or acquisition of water rights would be required in order to implement management on site.
2. The basis for requesting payment-in-lieu or private off-site mitigation is to be clearly demonstrated on the drainage plan.

This projects justification: This is a redevelopment and the existing developed conditions of the site are not able to reasonably provide the entire SWQ volume

Scott M McGee  
Professional Engineer or Architect

---

## **PAYMENT-IN-LIEU**

---

Per the DPM Article 6-12(C)(1), the amount of payment-in-lieu is deficient volume (cubic feet) times \$6 per cubic feet for detached single-family residential projects or \$8 per cubic feet for all other projects.

AMOUNT OF PAYMENT-IN-LIEU = \$ 1421 CF x \$8/CF = \$11,368

---

**THIS SECTION IS FOR CITY USE ONLY**

---

Waiver is approved. The amount of payment-in-lieu from above must be paid prior to Certificate of Occupancy.

Waiver is DENIED.



---

City of Albuquerque  
Hydrology Section