




TS AT 10'-0" O.C. TOOLED 1/4" ($\pm 1/16"$, -0) WIDE, 1" OR MAX. D/4
S GREATER. EXPANSION JOINTS AT 40' MAX. AND ALL P.C.'s, UNLESS
D OR INDICATED OTHERWISE ON PLAN VIEW JOINT PATTERN.



CONTRACTION JOINTS AT 10'-0" O.C. TOOLED 1/4" ($\pm 1/16"$, -0) WIDE, 1" OR MAX. D/4 DEEP WHICHEVER IS GREATER. EXPANSION JOINTS AT 40' MAX. AND ALL P.C.'s, UNLESS APPROVED OR INDICATED OTHERWISE ON PLAN VIEW JOINT PATTERN.



CONTRACTION JOINTS AT 10'-0" O.C. TOOLED 1/4" ($\pm 1/16"$, -0) WIDE, 1" OR MAX. D/4 DEEP WHICHEVER IS GREATER. EXPANSION JOINTS AT 40' MAX. AND ALL P.C.'s, UNLESS APPROVED OR INDICATED OTHERWISE ON PLAN VIEW JOINT PATTERN.



NOTE: BOLLARD HEIGHT SHALL BE 5'-0" AT DRIVE-THRU WINDOW



1.5" THICK ASPHALTIC CONCRETE SURFACE COURSE

2.5" THICK ASPHALTIC CONCRETE BINDER COURSE

6" THICK AGGREGATE SUBBASE SEE NOTE #1

EXTEND BASE 6" BEYOND FOR APPLICATIONS WITHOUT CURB & GUTTER, SIDEWALKS, BUILDINGS OR OTHER STRUCTURES.

IF PRESENT ON-SITE, UNSUITABLE SUBGRADE MATERIAL SHALL BE REPLACED WITH SUITABLE MATERIAL AS SPECIFIED IN THE GEOTECHNICAL REPORT.



NOTE:

1. GENERAL CONTRACTOR SHALL REFERENCE SITE SPECIFIC GEOTECHNICAL REPORT FOR PAVEMENT, AGGREGATE, AND SUBGRADE SECTION REQUIREMENTS.
2. MINIMUM PAVEMENT THICKNESS SHOULD BE 6" GRADED AGGREGATE BASE, 2.5" ASPHALT PAVEMENT BINDER & 1.5" ASPHALT PAVEMENT SURFACE COURSE TACK COAT.



ASPHALT PAVEMENT AND BASE COURSE

4000 PSI COMPRESSIVE STRENGTH CONCRETE

#3 @ 12" ON CENTER EACH WAY

PAVEMENT THICKNESS SEE NOTE #1

#4 REBAR FOR CONTINUOUS REINFORCEMENT OF THICKENED EDGE

9"

6" SUBBASE SEE NOTE #1

6" AGGREGATE BASE COURSE SEE NOTE #1



NOTE:
1. GENERAL CONTRACTOR SHALL REFERENCE GEOTECHNICAL REPORT FOR PAVEMENT SECTION REQUIREMENTS.

