

City of Albuquerque Stormwater Construction Site Inspection Report

General Information							
ESC File No.	H20EC	1 ,		Starbucks Albuquerque			
NPDES Id. No. NMR10				2004 Wyoming Blvd NE			
12/14/2023		Owner W. C. W. Coming NIM LLC			Contractor		
Operator		WFC Wyoming NM LLC Renaldo Gallagher					
Contact name & title e-mail		rgallagher@westfin.com					
Contact Phone #		770-344-8962					
					Start/End Time:	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	
COA Inspector		Chancellor English			· ·		
Construction Phase:		Pre-construction,					
Type of Inspection:		Regular	Storm Event			311/Complaint	Follow Up
	er at time of i		Cloud	ly	Tempera	ature: ~ 12/14/2023	45
<u>Estimated</u>	date of last s	torm 0.25" or	greater			12/14/2023	
Item	Deficiency/ Corrective Action						
Number	Deficiency/ Corrective Action						
	CM/DDD. The CM/DDD and self-inspection reports were unavailable at the site during the inspection in						
	SWPPP - The SWPPP and self-inspection reports were unavailable at the site during the inspection in						
	violation of CGP Parts 4.7.3 and 7.3. Inspections Plus sent SWPPP amendments after this inspection and						
	were reviewed. The review found the following that will be required in the SWPPP. Ensure that all						
	operators (owner, contractor) certify the SWPPP. A Delegation of Authority to certify SWPPP, SWPPP						
	modifications, corrective actions, and inspection reports cannot be assigned to a third party. The DoA is						
	usually given to the superintendent of the construction site. Ensure the SWPPP is modified when a						
	contractor is chosen for day-to-day operations (Areas of control, stormwater team, NOI, etc.). The						
	SWPPP Map needs to be amended to show the current location of the construction exit. Required						
	mitigation: You must keep a current copy of your SWPPP and self-inspection reports at the site or at an						
	easily accessible location so that they can be made available at the time of an on-site inspection per CGP						
	Parts 4.7.3 and 7.3. Ensure the Delegation of Authority meets the requirements listed in CGP Appendix						
	G Part G.11 and the EPA's Frequent Questions attachment.						
2.1	Discharge off site?	(Y/N)	no				
						10/1=/0	
4	Self Inspect	ion Reports	Yes	Latest rep	oort Date:	12/15/2	2023
Notes:							
Prior NOV for Posting, SWPPP, BMPs - all missing							
Received today's self-inspection, will need to be signed by the operators							
neceived today 3 sentinispection, will need to be signed by the operators							

City of Albuquerque Stormwater Inspector Signature and date: 12/18/2023

Contact information: Chancellor English (505) 924-3325

cenglish@cabq.gov

Chancellor English