## CITY OF ALBUQUERQUE



May 1, 2019

Barbara Felix Architecture + Design Barbara Felix 511 Agua Fria Street Santa Fe, NM **87501** 

Re:

Blake's Lotaburger LLC 3205 Richmond Dr NE Albuquerque NM 87107

**Traffic Circulation Layout** 

Engineer's/Architect's Stamp 04-22-19 (H21D012)

Dear Ms. Felix

Based upon the information provided in your submittal received 04-25-19, the above referenced plan cannot be approved for Building Permit until the following comments are addressed:

- The ADA accessible parking sign must have the required language per 66-7-352.4C NMSA 1978 "Violators Are Subject to a Fine and/or Towing." Please call out detail and location of HC signs.
- ADA curb ramps must be updated to current standards and have truncated domes installed.
- 3. Motorcycle parking spaces shall be designated by its own conspicuously posted upright sign, either free-standing or wall mounted per the zoning code.
- Per the IDO, a 6 ft. wide ADA accessible pedestrian pathway is required from the public sidewalk to the building entrances. Please clearly show this pathway and provide details.
- 5. Per DPM, a 6 ft. wide ADA accessible pedestrian pathway is required from the HC parking stall access aisles to the building entrances. Please clearly show this pathway and provide details.
- 6. ADA accessible pedestrian pathway should not be placed behind parking space or adjacent to a vehicular way. Vehicle and pedestrian/wheel chair conflicts should be avoided as much as possible.
- provide a copy of refuse approval.
- 8. Unused curb cuts must be replaced with sidewalk and curb & gutter. A build note must be provided referring to the appropriate City Standard drawing.
- 9. Please include **one** copy of the traffic circulation layout at the next submittal.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

Resubmit a revised plan along with fully completed Drainage Transportation Information Sheet to front counter personnel for log in and evaluation by Transportation. PDF copies of the plans and submittal package must be emailed to PLNDRS@cabq.gov at time of resubmittal. If you have any questions, please contact me at 924-3675.

Sincerely,

Mojgan Maadandar, E.I.

Associate Engineer, Planning Dept.

**Development Review Services** 

/MM via: email

C: CO Clerk, File